

## Chapter 3

### STRUCTURAL FIRE PRECAUTIONS

#### 3.1 GENERAL

- 3.1.1 The purpose of this chapter is to stipulate requirements to minimise the risk of spread of fire between adjoining buildings by separation, prevent the untimely collapse of buildings in the event of fire by the provision of a stable and durable form of construction and prevent the spread of fire between specified parts of the buildings by the division of such buildings into compartments.

*Structural fire precautions relate to the integrity and stability of building elements during fire for a required period of time. "Structural" does not only apply to the structural elements of buildings but other building components, e.g. doors, shafts, walls/ceiling finishes.*

*The objectives of structural fire precautions are :*

- (a) To prevent the spread of fire between adjoining buildings by adequate separation;*
- (b) To prevent the untimely collapse of building, including walls and floors of each unit in the event of a fire*
- (c) To prevent spread of fire from one unit to another within the building envelope by compartmentalising each unit with walls, floors and doors having the requisite fire resistance rating.*

#### 3.2 PROVISION OF COMPARTMENT WALLS AND COMPARTMENT FLOORS

- 3.2.1 Compartment size - floor area & cubical extent

Any building which has –

- (a) Any storey the floor area of which exceeds that specified as relevant to a building of that height in column (2) of Table 3.2A, or
- (b) A cubic capacity which exceeds that specified as relevant in column (3) of Table 3.2A,

shall be divided into compartments by means of compartment walls and compartment floors so that –

- (i) no such compartment has any storey the floor area of which exceeds the area specified as relevant to the building in column (2) of the Table, and
- (ii) no such compartment has a cubic capacity which exceeds that specified as relevant in column (3) of the Table.

Generally, the compartment size of factory or warehouse unit would not exceed 4000m<sup>2</sup> or a cubical extent of 15000m<sup>3</sup> as given in Table 3.2A which is reproduced below:

TABLE 3.2A SIZE LIMITATION OF BUILDING AND COMPARTMENT

(1) Compartments	(2) Maximum Floor Area	(3) Maximum Cubical Extent
Compartment below ground level. No compartment to comprise more than one storey.	2000m <sup>2</sup>	7500m <sup>3</sup>
Compartments between average ground level and a height of 24m. No compartment to comprise more than 3 storeys.	4000m <sup>2</sup>	15000m <sup>3</sup>
Compartments above a height of 24m from average ground level. No compartment to comprise more than one storey.	2000m <sup>2</sup>	7500m <sup>3</sup>

Compartment below ground level

- i) Under Table 3.2A no compartment shall comprise more than one storey and exceed floor area of 2000m<sup>2</sup> and a cubical extent of 7500m<sup>3</sup>. However, exceptions are allowed in the following situations:
  - a) Only 1<sup>st</sup> basement having a floor area of less than 100m<sup>2</sup> can form part of the 1<sup>st</sup> and upper storey compartment under Cl.3.2.5(a), provided the building is sprinklered protected including the basement.
  - b) Basement floors can be interconnected for use as car parking, if sprinkler system is provided.
- ii) Basement floor or compartment shall not be used for bulk storage of highly inflammable liquids or substances of any explosive nature.

Compartments between average ground level and a height of 24m

- i) No compartment shall comprise more than 3 storeys and floor area greater than 4000m<sup>2</sup> and cubical extent exceeding 15000m<sup>3</sup>. However, exceptions are allowed under clauses 3.2.3, 3.2.4(c) and 3.2.8.
- ii) High bay warehouse (HBW) and mechanised car parking buildings are treated differently from normal industrial buildings.

The requirement of restricting the compartment to max. 3 storeys would not be applicable. Such types of buildings are usually not occupied or have very limited people working in the premises.

Automatic sprinkler system and smoke extraction or venting system are required to be provided for high bay warehouses and mechanised car parking buildings which exceed 24m in building height.

Compartments above a height of 24m from averaged ground level

- i) No compartment shall comprise more than one storey and exceed the floor area of 2000m<sup>2</sup> and cubical extent of 7500m<sup>3</sup>.
- ii) This requirement would not apply to high bay warehouses and mechanised car parking buildings. Prior consent is to be obtained from SCD (FSSD) before submission of building plan.

General :

In computing the extent of a compartment, protected shafts e.g. lift, staircases etc and separately compartmented lavatory/locker room may be disregarded. See cl.1.2.16 under Definition in Vol. 1 of the handbook for further illustration.

Clause 3.2.2 only applies to PG VI Factory, not PG VIII Storage.

3.2.2 Cubical extent for compartment exceeding 4m in height

In computing the cubical extent of compartments in shops, similar premises and in single storey factory buildings, a height of 4m may be used where the actual height exceeds that figure, provided that this rule for measurement shall not be applied when a compartment comprises more than one storey or contains mezzanine, galleries or lofts.

For illustrations see Vol. 1 of Handbook on Definition on clause 1.2.16.

### 3.2.3 Relevant Authority may consent to greater size

Where however, the Relevant Authority is satisfied that additional floor area and cubical extent are necessary for any such building or compartment or part thereof, as aforesaid, he may consent to such additional floor area and cubical extent, provided:

- (a) Such building or compartment thereof is fitted throughout with an automatic sprinkler system which complies with the requirements in Chapter 6,
- (b) There is proper accessibility of site to fire fighting appliances, in compliance with the requirements in Chapter 4,
- (c) All other measures have been or will be taken and maintained for lessening so far as is reasonably practicable, any danger from fire.

Such consent shall continue in force only while such building or compartment is used for the purposes in respect of which consent was given.

(No illustration)

*Besides complying with sub-clause (a) & (b) above, the building or compartment shall not undergo change of use, change of storage materials and change of manufacturing processes. For example, a warehouse that was approved for storage of non-combustible materials (valves, steel bars & pipes) was subsequently used for storage of combustible materials (paper boxes) would require separate building plan submission and approval from SCDF (FSSD).*

*Similarly, a factory which was approved for the manufacturing of non-combustible products (precast beams, floors etc) would require separate building plan submission and approval from SCDF (FSSD) if there is a change of manufacturing process involving combustible materials.*

*In practice, where sprinkler system is provided, it would be taken that cubical compartment and floor area control under Table 3.2A has been relaxed, except max. 3 storey per compartment, unless further relaxation is allowed by SCDF (FSSD) because of smoke control system being provided.*

### 3.2.4 Compartmentation by height

- (a) In any compartment except those mentioned under sub-clause 3.2.4(d), up to a habitable height of 24m, no compartment shall comprise more than three storeys.




Diagram 3.2.4(a)

Where 3 storeys or levels form one compartment, the total floor area shall not exceed 4000m<sup>2</sup> and the total cubical extent shall not exceed 15000m<sup>3</sup>.

- (b) In any building which exceeds 24m in habitable height, no compartment shall comprise more than one storey for compartments at storey level exceeding 24m above average ground level.

(No illustration)

In any industrial building which exceeds 24m in habitable height, no compartment shall comprise more than one storey per compartment from storey level exceeding 24m above average ground level. There is a need to keep the fire compartment size small within 2000m<sup>2</sup> or 7500m<sup>3</sup> above that habitable height as it would otherwise pose difficulties to fire fighting and control of fire spread should there be a fire occurrence in one of those high-rise units.

- (c) The relevant Authority may consent to the relaxation of the requirements under Cl.3.2.4(a) and (b) for Atrium spaces provided the design of such spaces complies with the conditions stipulated for “Atrium” spaces.




Diagram 3.2.4(c)

Atrium design allows multiple floors to be connected even beyond the habitable height of 24m. The design would require the provision of engineered smoke control system and sprinkler system. The above clause allows atrium design in buildings, but prior approval from SCDF “FSSD” must be obtained before building plan submission can be made. See clause 1.2.5 of Definition under Vol. 1.

### 3.2.5 Other cases requiring compartment walls & compartment floors

The following situations shall require compartmentation by provision of compartment walls and/or compartment floors -

Separation of purpose groups

- (b) Any wall and floor separating part of a building from any other part of the same building which is used or intended to be used mainly for a purpose falling within a different purpose group, as identified under Table 1.2B, except the following:
- (i) Ancillary offices located within a building or compartment of purpose group VI and VIII.

- (ii) Rooms or spaces for ancillary usage located within a building or compartment of purpose group VI and VIII as stipulated under cl.1.2.2(B).




Diagram 3.2.5(c) - 1




Diagram 3.2.5(c) - 2

Compartment walls and floors shall be constructed of non-combustible materials to have minimum 1 hour fire resistance rating under Table 3.3A for any of the compartment.

### 3.2.5 (c) Floor over a basement

Any floor immediately over a basement storey if such storey -

- (i) forms part of a building or compartment of purpose groups VI and VIII; and
- (ii) has an area exceeding 100m<sup>2</sup>.




Diagram 3.2.5(c)(i)

Where the floor area of the basement exceeds 100sq.m it shall be a compartment below ground level and shall not comprise more than one storey. The basement floor shall be provided with sprinkler system under clause 6.4.1(d)(i) and dry riser under Cl. 6.2.1(b).




Diagram 3.2.5(c)(ii)

Where the floor area of basement is less than 100sq m, the floor over the basement need not be constructed as compartment floor. Openings can be created to connect the basement with upper storeys, subject to max.3 storey or level in a single compartment.

All basement floors, except those under Purpose Group I & II, are required to be provided with automatic sprinkler system under cl. 6.4.1(d)(i). Thus, where basement floor, irrespective of its floor area, is interconnected with upper storeys, the automatic sprinkler system required for the basement shall be extended to cover all the upper storeys.

Clause 3.2.5(d) prohibits more than one basement floor to be connected to form one compartment, except in the case of basement used solely for car parking.



3.2.5 (d) Basement floors

In any compartment below pavement level, no compartment shall comprise more than one storey, except in the case of basement used solely for car parking. No part of a basement storey shall be used for the bulk storage of highly inflammable liquids or substances of an explosive nature.




Diagram 3.2.5(d) - 1

Basement 1, which has a floor area of less than 100m<sup>2</sup> can be interconnected with 1<sup>st</sup> storey, provided it is compartmented from basement 2. Sprinkler system and rising mains are required to be provided to the building.




Diagram 3.2.5(d) - 2

Basement 1 having a floor area of more than 100m<sup>2</sup> is required to be compartmented from 1<sup>st</sup> storey. The above clause does not permit more than one basement storey per compartment unless solely used for car parking. Sprinkler system and rising main are required to be provided to basement.




Diagram 3.2.5(d) - 3

Owing to the special use where ramps or car lifts are needed to connect all the floors, compartmentation is relaxed where sprinkler system and rising main are provided.

(e) Fire command centre

The fire command centre shall be separated from other parts of the same building by compartment walls and floors having fire resistance of at least 2 hours.

(No illustration)

The fire resistance rating of the walls and floors shall comply with the elements of structure and shall have min. period of 2 hours. Any door opening into the Fire command centre from the occupancy area shall be min. 2 hour fire rated.

3.2.5 (f) Kitchen Separation

- (i) In an eating establishment, where a kitchen is required for the preparation of food and / or where 'open flame' cooking appliances are used, the kitchen shall be separated from other parts of the same building by compartment wall and floor having fire resistance of at least 1 hour;
- (ii) Openings in the compartment wall and floor shall comply with the relevant provisions of Cl.3.9 for protection of openings;

- (iii) Doors shall have fire resistance of half an hour and fitted with automatic self-closing device;
- (iv) Where the flue or duct passes through the compartment wall or floor, the flue or duct shall be encased by non-combustible construction to comply with the requirements of Cl.3.9.5 and no damper shall be permitted to be installed in such flue or duct; and

3.2.5 (f) (v) Separation requirement for kitchen could be exempted under the following conditions:-

- (a) when all the cooking facilities in the kitchen are fitted with approved extinguishing systems; or




Diagram 3.2.5(f)(a)

The above sub clause allows the kitchen not to be compartmented if the cooking hood or range is installed with an automatic fire suppression system, bearing PSB Label.

With this arrangement, there is no need to seek waiver approval from SCDF "FSSD".

- (b) when there are at least 25% of the perimeter walls (excluding air-well and void) of an eating establishment open directly to the external of the building, and provided any part of the floor space is within 9m from the nearest opening; or




Diagram 3.2.5(f)(v)(b) – 1




Diagram 3.2.5(f)(v)(b) – 2





Diagram 3.2.5(f)(v)(b) – 3



Section view of fixed louvre window

Diagram 3.2.5(f)(v)(b) – 4

In the above situation, kitchens are not required to be compartmented. Total ventilation openings provided along the external walls of 'a' and 'b' shall have minimum 25% of the floor area of kitchen and dining. No part of the floor space shall be more than 9m from the external openings. The openings referred to in walls 'a' and 'b' shall be unobstructed vertical openings for the passage of light and air, for example, in the case of fixed louvre window, the net ventilation opening between over-lapping louvres is 'x' as given in the above sectional drawing.

- (c) when there are at least 50% of the perimeter walls (excluding air-well and void) of an eating establishment open directly to the external of the building, and provided any part of the floor space is within 12m from the nearest opening; or




Diagram 3.2.5(f)(v)(c) – 1




Diagram 3.2.5(f)(v)(c) – 2

The 25% and 50% ventilation openings are required for smoke venting and relief of accumulated heat from the area on fire. This exemption cannot be applied in an enclosed air-conditioned environment, where the peripheral walls are fitted with glass panel.

The 25% and 50% ventilation openings are absolute values. Extrapolation of percentage ventilation openings based on depth of the eating establishment is not permitted.




Diagram 3.2.5(f)(v)(c) – 3

In the above diagram the kitchens are not required to be compartmented.

Ventilation openings along the external walls 'a', 'b', 'c' and 'd' shall be uninterrupted, having minimum 50% of the perimeter walls of the eating establishment. The openings to the air well shall not be included in this purpose.

The above requirement is more relevant to hawker centre type design.

- (d) when an eating establishment is separated from other parts of the same building by walls and floors having fire resistance of at least 1 hour and doors having fire resistance of at least half an hour; and provided –
- (i) for a sprinkler protected building, there is no need to control the floor area of the compartment; or




Diagram 3.2.5(f)(v)(d)(I) – 2

With the provision of sprinkler system, further relaxation is allowed to permit the whole eating establishment to be enclosed with at least 1 hour fire rated walls and  $\frac{1}{2}$  hour fire rated door. There is no restriction to the gross floor area of the eating establishments.

- (ii) for a non-sprinkler protected building, the floor area of the compartment shall not exceed 150m<sup>2</sup>;




Diagram 3.2.5(f)(v)(d)(ii) – 1

Under sub clause d(ii) where the building is not sprinkler protected, the area of the compartment, kitchen and dining area e.g (unit A) shall not exceed 150m<sup>2</sup>.

LPG cylinders provided for the 'open flame' cooking activities are not allowed to be located at the basement and the installation of LPG cylinders at other areas shall comply with provisions in the \*Fire Safety (Petroleum) Regulations.

\*Now known as Fire Safety (Petroleum and Flammable Materials) Regulations.

Notwithstanding all the above, the compartment where 'open flame' cooking activities is carried out shall not comprise more than one storey




Diagram 3.2.5(f)(v)(d)(ii) – 3



*Where 'open flame' cooking is used, the compartment comprising dining and kitchen areas shall not comprise more than one storey, notwithstanding the following :-*

- *Building is not sprinkler protected and the compartment does not exceed 150m<sup>2</sup>.*

*LPG cylinders shall not be used in any basement storey. However, piped gas is permitted in basement storeys.*

*In the case of eating establishment which comprises 2 storeys, then each storey shall be a fire compartment by itself.*

### 3.2.5 (k) Separation of motor vehicle workshop

A motor vehicle workshop shall be separated from any other part of the same building by compartment walls and floors having fire resistance of not less than 2 hours, and if located in a basement storey of a building, shall be separated from any other part of the same building by compartment walls and floors having fire resistance of not less than 4 hours.

(No illustration)

### 3.2.5 (l) Separation of spray painting room

- (i) Areas in which spray painting or other allied processes are performed or carried out, shall be separated from other parts of the same building by compartment walls and floors having fire resistance of not less than 2 hours. Where spray painting booths that have built-in vapour extraction system complying with NFPA 33, the fire resistance requirement is not applicable.
- (ii) Where a spray painting room or booth is protected by an automatic sprinkler system but not complying with NFPA 33, the fire compartment to the room or booth can be reduced from 2 hours to 1 hour.




Diagram 3.2.5(I)

*Spray painting booth or room shall be mechanically ventilated and enclosed in min. 2 hour fire rated compartment to allow spraying of paint to be carried out. It shall be constructed to prevent the escape of spray and flammable vapour which shall be removed by the exhaust system.*

*The exhaust discharge point shall be not less than 5m from the inlet of any mechanical ventilation system.*

### 3.2.5 (m) Coldroom

- (i) Where a coldroom has a floor area exceeding 10 sq m, a separate outer layer of non-combustible construction, including the door, having minimum 1-hour fire resistance rating, shall be provided to compartmentalise the coldroom enclosure from other areas.




Diagram 3.2.5(m)-1

The main concern about coldrooms is the use of combustible insulation materials for the construction of the coldroom walls, ceilings and floors. The insulation material is usually polystyrene or polyurethane which when subject to a fire would burn vigorously to release great amount of heat and thick poisonous fumes.

The above diagram illustrates a cluster of coldrooms in a food processing factory, which is sprinklered protected. The aggregate floor area of the coldrooms is more than 20 sq m. Hence, the provision of 1-hour fire rated outer skin of compartment walls and doors would be necessary.

- (ii) Provision of the fire resisting outer layer enclosure, including the fire door, to the coldroom would not be required if :
- \* The coldroom has a floor area not exceeding 20 sq m and is sprinkler protected in a building, and the storage materials shall not include highly flammable chemicals.
  - \* The coldroom is located in a kitchen compartment (with or without 'open flame' cooking appliances) in an eating establishment, provided the floor area of the coldroom does not exceed 20 sq m, and the kitchen is compartmentalised from other parts of the building by compartment walls and floor having minimum 1-hour fire resistance and door having minimum ½-hour fire resistance, irrespective of the relaxation allowed under cl.3.2.5(f)(v)




Diagram 3.2.5(m)-2

The aggregate floor area of all the coldrooms shall not exceed 20sq m if located in a kitchen that is enclosed with 1-hour fire rated compartment walls and 1/2 -hour fire door.




Diagram 3.2.5(m)-3

As the aggregate floor area of the coldrooms No. 1 and 2 is greater than 20 sq. m, each coldroom is to separately fire compartmented with one hour fire rated compartment walls and fire door. The 1-hour fire rated coldroom doors, swing or sliding type, are accepted for use, provided they are listed under the PSB product listing scheme.

### 3.2.5 (n) Store room

For non-sprinklered buildings, if the area of the store room exceeds 10 m<sup>2</sup>, it shall be compartmented from the other parts of the same building by compartment walls and floors having fire resistance of not less than 1 hour. No fire compartmentation is required for a store room which is housed within a sprinklered protected building.




Diagram 3.2.5(n)

*Store 1 exceeding 10m<sup>2</sup> inside a factory space will need to be compartmentalised with 1- hour fire rated enclosures.*

*For Store 2, which is located within a warehouse space need not to be separately compartmented.*

*Store 3 which is less than 10m<sup>2</sup> still required to be provided with fire door as the store opens into internal escape corridor.*

### 3.2.5 (o) Areas of Special Hazard

Areas of special high risk in a building

- (i) Boiler rooms, transformer rooms, generator rooms, storage areas of materials that are highly combustible or flammable, and any other area of special high risk shall be separated from other parts of the building by compartment walls and floors having fire resistance of not less than 2 hours. If the building is protected by an automatic sprinkler system, the fire resistance rating of the compartment walls and floors can be reduced to 1 hour.

- (ii) Rooms housing transformer containing flammable liquid and generator rooms shall be located against an external wall.




Diagram 3.2.5(o)

Transformer and generator rooms that contain flammable liquids should be located against an external wall for external ventilation and explosion relief.

#### Transformer room

Transformers could be dry type or oil cooled type. Oil cooled type is to be located against an external wall above ground level to allow for external ventilation and explosion relief. Adequate precautions should be taken by the provision of a suitable catch pit or other means to prevent the spread of fire resulting from leakage and ignition of oil.

#### Generator rooms

Generator sets shall be located in clean, dry locations within fire rated compartments. They may be placed outdoors if they are of purpose built type, provided proper separation from unprotected openings of the building is maintained. Generator rooms shall be located against an external wall above ground level to allow for external ventilation and explosion relief.

#### Storage areas of highly combustible or flammable materials

Where possible, oil storage tanks should be installed in open air at ground level at least 6m from adjacent buildings and in accordance with CP 40. A max. capacity of 700 litres of diesel oil is permitted to be stored in the generator room. The oil drum/s shall be located within a bunded area, capable of containing 100% spillage from the drum/s.

Prior approval is to be obtained from SCDF (FSSD) for storage of combustible or flammable liquids, other than in the generator room, before building plan submission.

### 3.2.5 (p) Tenancy units

Fire compartmentation between individual tenancy units within a terraced or flatted factory building shall be provided. The entire enclosure of each of these units shall be fire compartmented with walls and floors of minimum one-hour fire resistance rating.

#### Tenancy unit




Diagram 3.2.5(p)-1

Compartment wall between units is required to be constructed of non-combustible materials having minimum 1-hour fire resistance rating.




Diagram 3.2.5(p)-2

Enclosing walls and doors to internal corridor are required to be constructed of non-combustible materials having the necessary fire resistance rating. Walls and doors facing the external corridor are not required to be fire rated.




Diagram 3.2.5(p)-3

Compartment wall between units are required to be constructed of non-combustible materials having minimum 1-hour fire resistance rating.

### 3.2.6 Provision for atrium spaces

The relevant Authority may consent to modify the requirements under Cl.3.2.1 and 3.2.4(a) and (b) of this Code for the design of "Atrium spaces" in a building provided the following conditions are complied with :

- (a) The minimum plan area of the Atrium void shall be not less than 93m<sup>2</sup> and no horizontal dimension between opposite edges of the floor opening is less than 6m wide: and
- (b) Occupancy within the floor space of the Atrium meets with the specification for low or ordinary hazard content; and
- (c) The atrium is open and unobstructed in a manner such that it may be assumed that a fire in any part of the space will be readily obvious to the occupants before it becomes a hazard; and
- (d) The building is fitted throughout with an automatic sprinkler system to comply with the requirements in Chapter 6; and
- (e) The building is fitted with an engineered smoke control system in accordance with cl.7.6; and



- (f) Provision of openings and enclosures, and the planning of means of escape shall be subject to the approval of the Relevant Authority.




Diagram 3.2.6

The above clause allows the SCDF (FSSD) to vary the max. floor area/cubical extent of fire compartment to allow more than 3 storeys to be interconnected even beyond the habitable height of 24m. The critical requirements to comply with would be the size and configuration of atrium void and provision of sprinkler system and engineered smoke control system.

QPs shall note that all atrium designs are required to be vetted and cleared by SCDF (FSSD) before building plan submission. The vetting refers to the concept and the location of atrium void in the building proposal only. Calculations for the engineered smoke control system shall be submitted separately by M&E qualified persons.

### 3.2.7 Buildings of High Hazard Occupancy

- (a) The compartment of buildings of high hazard occupancy shall not exceed one half of the sizes given in Table 3.2A and each compartment shall comprise one storey; and
- (b) No storey of a building, the habitable height of which is more than 24m, shall be used for the bulk storage of goods or substances of highly combustible nature unless the building is provided with a sprinkler system to comply with Chapter 6; and
- (c) The type of storage materials or substances shall not include the following:

- (i) material that will flame up by themselves without the presence of any fire source below the ignition temperature of 200°C; and
- (ii) combustible / highly flammable materials which include those highlighted in sub-clauses (a), (b), (c) and (d) of cl.1.2.39.




Diagram 3.2.7

- a) Warehouse compartments A, B & C shall not exceed 2000m<sup>2</sup> and 7500m<sup>3</sup>. Each compartment shall comprise one storey only. The materials to be stored in the warehouses shall exclude those listed under subclause c(i) & (ii).
- b) Buildings with habitable height not exceeding 24m are allowed to be used for bulk storage of goods or substances of highly combustible nature, except those listed under subclause c(i) & (ii). However, if the above mentioned warehouse buildings exceed the habitable height of 24m, the whole building must be protected with automatic sprinkler system. Irrespective of the building height, subclause (a) shall be complied with.
- c) Materials as listed under subclause c(i) & (ii) are not allowed to be stored in any multi-storey building, irrespective of the habitable height.

### 3.2.8 Exemption from CL.3.2.1 on size limitation of compartment

The requirements of Cl.3.2.1 may be exempted under the following circumstances:

- (a) Buildings used solely for the sale, storage, processing and packaging of goods and substances of a non-combustible nature, provided that any other parts of the buildings used otherwise as described shall be separated by compartment

walls and compartment floors in compliance with the requirements of the relevant provisions for compartment walls and compartment floors, and

- (b) Single storey buildings of Purpose Group VI, provided that the buildings are used solely for the sale, storage, processing & packaging of goods & substances of a non-combustible nature, and
- (c) Open sided car parking decks having not less than 50% of the sides permanently open and such openings being evenly distributed as to provide cross ventilation to all parts of the car parking areas.

(a) & (b) – (No illustration)

*For buildings or parts of building used for sale, storage, processing and packaging of goods and substances of a non-combustible nature, there is no specific limit of cubical extent or floor area. Each case will be considered on its merit, having regard to fire engine accessibility provided to the site and the risk to adjacent buildings. Prior approval from SCDF (FSSD) shall be obtained before building plan submission. Any portion of the building that is used otherwise than as described above should be separated from the remainder part of the building by floors, walls and protected exit staircases having the necessary fire resistance rating as the elements of structure of the building; and having the floor area and cubical extent complying with Table 3.2A.*

A typical standalone multi storey car park having good cross ventilation and meeting the above sub-clause (c) of having not less than 50% of the sides permanently open




Diagram 3.2.8 – 1

Size limitation of the car parking floors is exempted

As the habitable height is less than 24m, automatic sprinkler system is not required. The clear width of the airwell shall not be less than 1800mm to prevent fire from a car from spreading vertically between split level. Provision of fire alarm system shall be in accordance with Table 6.4A of the Fire Code.

A multi-storey car park vertically fire separated from another building




Diagram 3.2.8 – 2

Attached multi-storey car park is required to be protected by sprinkler system. The multi-storey car park would qualify for exemption on size limitation of compartment if sub-clause (c) is fully complied with.




Diagram 3.2.8 - 3

In the above situation where car parking decks form part of the multi-storey development, having a habitable height greater than 24m, automatic sprinkler system is required to be provided to cover the whole building. As for car parking decks, the cubical extent and floor area could be relaxed due to cross-ventilation under sub-clause (c).

### 3.3 FIRE RESISTANCE OF ELEMENTS OF STRUCTURE

3.3.1 Subject to an expressed provision to the contrary, any element of structure shall be constructed of non-combustible materials (excluding materials of limited combustibility) and to have fire resistance for not less than the relevant period specified in Table 3.3A having regard to the purpose group of the building of which it forms a part and the dimensions specified in that Table, provided that –

(a) Any separating wall shall have fire resistance of not less than 1-hour, and

(No illustration)

(b) Any compartment wall or compartment floor which separates a part of a building falling within Purpose Group II or III from any other part of the building falling within a Purpose Group other than Purpose Group II or III shall have fire resistance of not less than 1-hour.




Diagram 3.3.1(b)

3.3.2 Exemption for non-load bearing external walls

Nothing in Cl.3.3.1 shall apply to :

(a) any part of any external wall which is non-load bearing and may, in accordance with Cl. 3.5 be an unprotected area.




Diagram 3.3.2

Any part of a non-load bearing external wall which constitute the unprotected opening in pursuance to clause 3.5, is not required to have any fire resistance. In the above diagram, the non-load bearing external wall facing the public road need not have fire resistance if it meets Cl.3.5 on set-back requirement, measured from the centre of the public road to the external wall.

### 3.3.3 Exemption for single storey buildings

In the case of a single storey building consisting of a first storey and one or more basement storeys, nothing in Cl.3.3.1 shall apply to any element of structure which forms part of the first storey and consists of –

- (a) A structural frame or a beam or column, provided that any beam or column (whether or not it forms part of a structural frame) which is within or forms part of a wall, and any column which gives support to a wall or gallery, shall have fire resistance of not less than the minimum period, if any, required by this code for that wall or gallery, or




Diagram 3.3.3(a)

- (i) *The structural frame or beams and columns of a single storey building need not have fire resistance under Table 3.3A, unless otherwise specified by the Relevant Authority. The qualified persons shall, before making building plan submission, consult SCDF (FSSD) as to the need for protection of beams and columns in the following situations :*
- a) *Single storey factory or warehouse involving high hazard materials;*
  - b) *Single storey factory or warehouse having an extensive footprint; and*
  - c) *Single storey warehouse exceeding a building height of 10m.*
- (ii) *However, any beam or column which is within or forms part of a compartment wall, separating wall or external wall (which require to have fire resistance under clause 3.5) shall be required to have the same fire resistance rating as the wall in which such beam or column forms part of.*
- (iii) *Any column or beam which give support to a wall or gallery, shall have the same fire resistance as that required for the wall or gallery, e.g. column and beam supporting the external wall or mezzanine floor which are required to have fire resistance.*
- (b) *An internal loadbearing wall or a loadbearing part of a wall, unless that wall or part is, or forms, part of a compartment wall or a separating wall, or forms part of the structure enclosing a protected shaft or supports a gallery, or*




Diagram 3.3.3(b)

An internal loadbearing wall or a loadbearing part of a wall is not required to have fire resistance under Table 3.3A, provided the wall is not –

- i) forming part of or a compartment or separating wall
  - ii) forming part of the structure enclosing a protected shaft e.g. exit staircase; or
  - iii) supporting a gallery
- (c) Part of an external wall which does not support a gallery and which may, in accordance with Cl.3.5 be an unprotected area.




Diagram 3.3.3(c)

External wall which does not support a gallery and has adequate setback from the boundary in accordance with Cl.3.5 to be an unprotected area need not have fire resistance under Table 3.3A.

### 3.3.4 Interpretation and application of this regulation

The interpretation and application of Cl.3.3 shall be as follows:

- (a) Subject to the provisions of sub-cl.(b) and any other expressed provision to the contrary, any reference to a building of which an element of structure forms a part means the building or (if the building is divided into compartments) any compartment of the building of which the element of structure forms a part, and






Diagram 3.3.4(a)

Any reference to a building, which is divided into compartments, of which an element of structure forms a part, means that compartment of the building (Building A).

Any reference to a building of which an element of structure forms a part means the building (Building B). It is important to note that any element carrying another element of structure must have at least the same fire resistance as the element it is supporting.

- (b) Any reference to height means the height of a building, but if any part of the building is completely separated throughout its height both above and below ground from all other parts by a compartment wall or compartment walls in the same continuous vertical plane, any reference to height in relation to that part means the height solely of that part, and




Diagram 3.3.4(b)

The continuous vertical compartment wall divides the building into 2 parts. For building A, any reference to height means the building height (A). For building B, any reference to height means the building height (B). The above clause is intended to provide relaxation for the lower building

- (c) If any element of structure forms part of more than one building or compartment and the requirements of fire resistance specified in Table 3.3A in respect of one building or compartment differ from those specified in respect of any other building or compartment of which the elements forms a part, such element shall be so constructed as to comply with the greater or greatest of the requirements specified.




Diagram 3.3.4(c) – 1

The warehouse as podium and factory sited on top helps to explain the fire resistance of the lower and higher structure under Table 3.3A, bearing in mind that the lower structures in relation to the fire resistance rating must be able to sustain the upper higher structures of the building sited on top.

For instance, a podium of 2 storey office development (cubical extent >14,000m<sup>3</sup>) requires a minimum 1½ hour fire resistance rating for elements of structure and a 5 storey flatted factory (cubical extent >5,500m<sup>3</sup>) sited on top of the podium requires a minimum 2 hour fire resistance rating for elements of structure. In such scenario, the lower structures for the 2 storey office elements of structure should be that of minimum 2 hour fire resistance rating instead of 1½ hour fire resistance rating. The rationale is that the lower structures must be able to sustain the structural loads of the upper building.




Diagram 3.3.4(c) – 2




Diagram 3.3.4(c)-3

- 3.3.4 (d) If any element of structure is required to be of non-combustible construction, the measure of fire resistance rating shall be determined by the part which is constructed wholly of non-combustible materials. (With the exception of fire protecting suspended ceilings, surface materials for walls and ceilings and floor finishes may be combustible, if they are not relied on to contribute to the fire resistance of the wall or floor).

(No illustration)

### 3.3.6 Suspended ceiling

In determining the fire resistance of floors, no account shall be taken of any fire resistance attributable to any suspended ceiling unless the ceiling is constructed specifically as a fire protecting suspended ceiling and the construction complies with the requirements under Table 3.3B for Limitations on Fire Protecting Suspended Ceilings.




Diagram 3.3.6

The ceiling shown in diagram 3.3.6 above, shall be constructed specifically as a fire protecting membrane and comply with Table 3.3B on limitation of fire protecting suspended ceiling. As the ceiling is intended as a protecting membrane, the concealed ceiling space shall not be used for recessed lighting and other service, such as air-con ducts, cables, pipes etc, even if these services are housed in fire rated enclosures.

Where the space above a suspended ceiling (non-fire rated) is protected by an automatic sprinkler system it shall be exempted from the requirements for non-combustibility and surface spread of flame classification as specified in the above Table, provided the ceiling is not situated over an exit passageway, protected lobby or other required protected means of escape, and that the ceiling space is not used as an air-plenum.

The implications of clause 3.3.6 are that the normal type of suspended ceiling consisting of separate tiles cannot be counted as contributing to the fire resistance of the floor in buildings over 15m high where the period required is one hour; or in buildings of any height where the period required is more than one hour. In these circumstances only jointless ceilings can be considered as contributing.

The above diagram showing protective ceiling being added to the underside of a timber floor, shall apply only to buildings under conservation where retention of the timber floor is required, and in buildings under Purpose Groups I & II for the construction of attic.

### 3.3.7 Fire rated board

Fire rated boards are permitted to be used for protection to structural steel beams and columns in building not exceeding the habitable height of 24m; and to beams only, except load-bearing transfer beams, in building exceeding the habitable height of 24m; if the following conditions are satisfactorily fulfilled:



*Diagram 3.3.7*

- (i) Material shall be non-combustible (BS476 Pt 4 or Pt 11); and
- (ii) It shall have fire resistance for not less than the relevant period specified in Table 3.3A having regard to the purpose group of the building of which it forms a part and the dimensions specified in that Table; and
- (iii) It shall meet the criteria, in terms of water absorption and bending strength performance, when subject to test of BS1230 Pt 1 (for gypsum plaster board) or ISO 1896 (for calcium silicate or cement board); and
- (iv) The fire rated boards shall be constructed to be in contact with the steel column. If it is unavoidable, the void space between the fire rated board and the steel column shall be adequately filled to a height of 1.2m, measured from finished floor level, with fire protective material such as concrete, gypsum or grout to prevent any possible denting of the boards; and

- (v) For purpose group VI building, the fire rated boards for the protection of columns shall be protected against mechanical damage to a minimum height of 1.2m, measured from finished floor level, by heavy duty metal guard to prevent damage of the board by moving forklift, etc. For such cases, the requirement of filling up the void space may be dispensed with; and
- (vi) There shall be no services running in the space between the steel structure and fire rated boards, unless these services are encased in concrete or run in steel conduits.

(No illustration)

*Running of services in the space between the steel structure and fire rated boards should be discouraged, unless it is unavoidable.*

*Services shall be limited to cables only and shall not include duct, gas pipes, fuel oil pipes, etc.*

### **3.4 TESTS OF FIRE RESISTANCE**

#### **3.4.1 Fire resistance**

Performance for the fire resistance of elements of structure, doors and other forms of construction shall be determined by reference to the methods specified in BS 476:Part 20 to 23, which specify tests for stability, integrity and insulation.

Specific requirements for each element in terms of the three performance criteria of stability, integrity and insulation are given in Table 3.4A,

(No illustration)

*In conjunction with Part 20, methods of test are provided for – Beams, columns, floors, flat roofs and walls(Part 21); Partitions, doorsets and vertical shutter assemblies, ceiling membranes and glazed elements(Part 22); and Suspended ceilings protecting steel beams and intumescent seals for use in conjunction with single acting latched timber fire-resisting door assemblies(Part 23).*

*Part 20 specifies standard heating conditions based on a temperature/time curve (Diagram 3.4.1) which furnaces are required to follow; the temperature at defined locations close to the exposed face of the specimen under test rising to 821°C after 30 minutes and 1133°C after four hours.*



*"Insulation"*

- *the ability of a separating element to resist an excessive rise in temperature on its unexposed face.*

*The criterion of "stability" or "loadbearing capacity" is applied only to loadbearing elements. For floors, flat roofs and beams, allowable vertical deflection is limited to 1/20 clear span.*

*Loss of "integrity" in the context of the formation of holes, gaps or fissures is judged by ignition of a cotton fibre pad. Where this test is not suitable, failure is deemed to have occurred if either a 25mm diameter gauge can penetrate into the furnace through a gap at any point, or a 6mm diameter gauge can penetrate into the furnace through an opening and can be moved for a distance of at least 150mm.*

*Loss of "insulation" occurs when the temperature on the unexposed face (the side of the specimen remote from the furnace) increases by more than 140°C (mean) or by more than 180°C at any point. Loss of "integrity" also constitutes loss of "insulation".*

*Columns and beams have to satisfy only the criterion of "loadbearing capacity"; glazed elements are normally required to satisfy only "integrity"; and floors and walls have to satisfy all three criteria. It is pertinent to note that under Table 3.4A, doors are only required to satisfy "integrity", leaving aside "insulation" as it is assumed unlikely that combustible materials would be stored against them. However, doors to protected lobbies, exit staircases and exit passageways should be provided with insulation against transmission of heat by radiation from the fire floor into the protected enclosures which occupants use for evacuation.*

*It is important to note that fire rated glass door shall not be used in protected lobbies, exit staircases and exit passageways.*

### 3.4.2 "Deem to satisfy" provisions

An element of structure, door or other part of a building shall be deemed to have the requisite fire resistance if –

- (a) It is constructed to the same specification as that of a specimen exposed to test by fire in accordance with the method and procedure under BS 476: Part 20 to 23, and satisfied the requirements of that test for the three performance criteria of stability, integrity and insulation for not less than the specified period, or
- (b) In the case of a wall, beam, column, stanchion or floor to which Appendix A to Cl.3.4 relates, it is constructed in accordance with one of the specification set out in that Appendix and the notional period of fire resistance given in that Appendix as being appropriate to that type of construction and other relevant factors is not less than the specified period.



(No illustration)

Sub-clause 3.4.2(b) provides the alternative to complying with the specification of tested prototype under BS476 Part 20 to 23. Specification set out in Appendix A to Cl.3.4 could be used and there is no need to obtain separate testing. However, on completion of the building works, the qualified person concerned is to forward to SCDF "FSSD" his/her certificate of supervision that the relevant specification listed in Appendix A to Cl. 3.4 had been complied with on site when applying for TFP or FSC.

### 3.4.3 Timber floors

The use of timber floors shall not be allowed.

## 3.5 EXTERNAL WALL

### 3.5.1 Requirements of External Walls shall be as follows:

- (a) Any external walls of a building or a separated part of a building which constitutes or is situated within a distance of 1m from any point on the relevant boundary, or is a wall of a building or a separated part of a building which exceeds 15m in height shall-
  - (i) be constructed wholly of non-combustible materials apart from any external cladding which complies with Cl.3.5.4 or any internal lining which complies with Cl.3.13.4, and
  - (ii) be so constructed as to attain the fire resistance required by this chapter, and




Diagram 3.5.1 – (1)




Diagram 3.5.1- (2)

- \* External wall of a building which exceeds 15m in building height or is within 1m of the relevant boundary shall be constructed wholly of non-combustible materials, apart from any external combustible cladding under Cl.3.5.4 or internal combustible lining under Cl.3.13.4.
- \* The external wall shall be imperforate, free of any unprotected area and have the necessary fire resistance rating, both inside and outside. The required fire resistance shall be achieved by the non-combustible part alone.
- \* The external wall shall have the necessary fire resistance rating as follows:  
  
the elements of structure of the building or compartment in which the wall is located at least 1m away from in accordance with Table 3.3A, Part 1.
- \* The whole or part of an external wall need not have fire resistance rating and can be treated as unprotected area (such as windows etc) if it is adequately separated from the relevant boundary in accordance with Table 2 to Cl.3.5 of the Fire Code. Walls which are more than 1m from a boundary need to resist the effect of fire from the inside only.

- 3.5.1 (b) Any beam or column forming part of an external wall and any structure carrying an external wall which is required to be constructed of non-combustible material, shall comply with the provisions of sub-cl. (a)

(No illustration)

Any beam or column forming part of an external wall and any structure carrying an external wall shall be constructed of non-combustible materials and have the necessary fire resistance rating of elements of structure, apart from any external cladding which complies with Cl.3.5.4 or any internal lining which complies with Cl.3.13.4. The required fire resistance shall be achieved by the non-combustible part alone.

### 3.5.2 Exceptions

The requirements of Cl.3.5.1(a)(i) for non-combustibility of external walls shall not apply to the external wall of a building or separated part of a building-

- (a) If that wall is :
- (i) situated 1m or more from the relevant boundary; and
  - (ii) not exceeding 15m in height; and
  - (iii) separated as described in Cl.3.3.4(b); or




Diagram 3.5.2(a)

Part of a factory or warehouse building (not exceeding 15m – building A in diagram 3.5.2(a) - 1), separated from the other parts by vertical compartment wall. Exemption would also apply to the separated part of building A in diagram 3.5.2(a) - 1 which shall not exceed 15m in height and be situated 1m or more from the relevant boundary.

- (b) if that wall is situated 1 m or more from the relevant boundary:
- (ii) of single storey construction and not exceeding 15 m in height and floor area not exceeding –
    - purpose group VI - 2000 m<sup>2</sup> ;
    - purpose group VIII – 500m<sup>2</sup>

Or

- (iii) other than single storey buildings, but not exceeding 7.5 m in height and floor area not exceeding -  
purpose group VI - 250 m<sup>2</sup> .

### 3.5.3 Unprotected areas in any side of a building

Except where otherwise provided, unprotected areas in any side of a building shall comply with the following:

- (a) Any relevant requirements relating to the permitted limits of unprotected areas specified in Appendix B unless the building is so situated that such side may be in accordance with Appendix B consists entirely of any unprotected area, and

(No illustration)

*Unprotected areas in relation to a side or external wall of a building means:*

- (i) *a window, door or other opening, and*
- (ii) *any part of the external wall which has less than the relevant fire resistance required in cl.3.5, and*
- (iii) *any part of the external wall which has combustible material more than 1mm thick attached or applied to its external face whether for cladding or any other purpose*

*The extent of unprotected areas in the external wall in relation to the setback from relevant boundary or lot boundary shall be in accordance with Appendix B to Cl.3.5. The further the building is setback from the relevant boundary, the greater the amount of unprotected areas would be permitted.*

*An example on calculations of unprotected openings/setback from relevant boundary is given in page 56. The intensity of the heat produced by a fire within a building which can reach the relevant boundary will depend upon the extent of the "unprotected areas" in the external walls and the distance between these walls and the relevant boundary. The heat flux at the relevant boundary shall be less than that normally required for pilot ignition of combustible material after a period of exposure.*

*Thus, there is need to control the extent of "unprotected area" which can be permitted in relation to the distance from the relevant boundary.*

*In situations where the extent of unprotected areas in external walls do not comply to Appendix B, the qualified person has 4 alternatives. These are:*

- (a) *reduce the total unprotected area; or*

*(b) increase the distance from the relevant boundary; or*

*(c) introduce compartmentation within the building to break up the size of enclosing rectangle or*

*(d) introduce automatic sprinkler system so that the unprotected areas can be doubled or the distance from the relevant boundary can be reduced by half.*

(b) The extent of unprotected openings in an external wall of a building or compartment in relation to its distance from the lot boundary may be double that which is specified in Appendix B when the building or compartment is :

(i) used solely for the sale, storage and processing involving goods and substances of a non-combustible nature, or

(ii) fitted throughout with an automatic sprinkler system in compliance with the requirements in Chapter 6.

(No illustration)

*Warehouse used for storage of valves, steel bars & pipes are of non-combustible nature. Storage used for combustible materials such as paper box would require separate building plan submission and approval from SCDF "FSSD".*

*For subclause b(ii), more relaxation is granted with installation of sprinkler system taking into consideration the expected fire size.*

(c) The distance between the external wall of a building and the relevant boundary may be half that specified in Appendix B if the building is fitted throughout with an automatic sprinkler system in compliance with the requirements in Chapter 6.

(No illustration)

*The above clause is to provide an alternative for buildings protected with sprinkler system. Qualified Person/Building owner shall decide which option, clause (b) or (c) i.e either double the unprotected openings or half the separation distance between the building and the relevant boundary, whichever is relevant to the building.*

(d) The extent of unprotected openings in an external wall of a building or part of building used for carparking in relation to its distance from the lot boundary or relevant boundary may be based on the floor having the largest extent of unprotected openings for the purpose of complying with Table 1 of Appendix B.




Diagram 3.5.3(d)

The above clause treats car park building differently by allowing the floor having the largest extent of unprotected openings to be used for the purpose of complying with Table 1 of Appendix B. This clause grants special relaxation in relation to its distance from the lot boundary for the purpose of complying with Table 1 of appendix B.

In the above diagram, the enclosing rectangle would apply to 1<sup>st</sup> storey elevation facing the relevant boundary, instead of the whole building, which forms one compartment.

#### 3.5.4 Cladding on external walls

(a) If such cladding is situated less than 1 m from the relevant boundary, it shall have surface complying with the requirements for Class '0'.

3.5.4 (b) If such cladding is situated 1 m or more from the relevant boundary it shall have, if the building is more than 15 m in height, a surface complying with the requirements specified for Class '0', except that any part of such cladding below a height of 15 m from the ground may consist of timber of not less than 9 mm finished thickness or of a material having a surface which, when tested in accordance with BS 476: Part 6 have an index of performance (I) not exceeding 12 and a sub-index ( $i_1$ ) not exceeding 6.




Diagram 3.5.4(a)

If such cladding is situated 1m or more from the relevant boundary and the building is more than 15m,

- (i) any part that is situated above 15m from the ground shall have a surface complying with the requirements for Class '0'.
- (ii) any part that is situated below a height of 15m from the ground may consist of timber of finished thickness greater than 9mm or of a material having a surface which, when tested in accordance with BS 476 Pt 6 has an index of performance (I) not exceeding 12 and a sub-index  $i_1$ , not exceeding 6. The index of performance is derived from the fire propagation test which provides a comparative measure of the contribution a material will make to the heat build-up and thus to fire spread within a room or space.
- (iii) Values of index of performance (I) range in descending order of merit from '0' (non-combustible material eg. metal) to '100' (highly combustible material). For example, 13mm thick fibre insulation board has an index of performance (I) 66.4 and a sub-index  $i_1$ , 41, 18mm thick hardwood has the value of 34.9 and a sub-index  $i_1$ , 9.5 and 13mm thick plaster board has the value of 9.9 and a sub-index  $i_1$ , 5.8. Low values indicate a low rate of heat release.
- (iv) Values of index of performance (I) is obtained from :  $I = i_1 + i_2 + i_3$  where sub-index  $i_1$ , is derived from the first three minutes of test,  $i_2$  from the following seven minutes, and  $i_3$  from the final ten minutes. A high index  $i_1$  indicates an initial rapid ignition and heat release.

### 3.5.5 Reference to Part I - II of Appendix B

Any reference to Appendix B shall be construed as referring to the provisions of Part I of that Appendix together with the provisions of Part II.

(No illustration)

## APPENDIX 'B' TO CL.3.5


### PART 1

### CALCULATION OF PERMITTED LIMITS OF UNPROTECTED AREAS

General rules applicable to this Appendix

1. The permitted limit of unprotected areas in any side of a building or compartment shall be calculated by reference to the requirements of Part II or III (whichever is applicable under Cl.3.5)

#### Unprotected Areas in External Wall



2. For the purpose of this Appendix, the expression "unprotected area" has the meaning ascribed to it by Cl.1.2.61, but in calculating the size of unprotected areas or the permitted limit of unprotected areas, the following provisions shall apply -
  - (a) Where any area of an external wall is an unprotected area, only because it has combustible material attached to it as cladding, the area shall be deemed to be half the area of such cladding;






Diagram 2(a) Pt.I Appendix B

$$\text{Total unprotected area} = W \times H - \frac{1}{2} (W \times h1)$$

(b) No account shall be taken of the following –

- (i) an unprotected area which does not exceed 0.1m<sup>2</sup> and which is not less than 1.5m from any other unprotected area in the same side of the building or compartment (unless that other falls within (iii) below);
- (ii) one or more unprotected areas having an areas (or, if more than one, the aggregate area) not exceeding 1m<sup>2</sup> and not less than 4m from any other unprotected area in the same side of the building or compartment (except any such area as is specified in (1) above);
- (iii) an unprotected area in any part of an external wall which forms part of a protected shaft;
- (iv) an unprotected area in the side of a building not divided into compartments, if the area is not less than 28m above any ground adjoining that side of the building.

No account shall be taken of the following :-

- (i) Unprotected area not exceeding 0.1m<sup>2</sup> and not less than 1.5m from other unprotected area




Diagram 2(b)(i) – Pt. I Appendix B

- (ii) Unprotected area or aggregate area not exceeding 1m<sup>2</sup> and not less than 4m from other unprotected area






Diagram 2(b)(ii) – Pt. I Appendix B


- (iii) Unprotected area in external wall of protected shaft



No account shall be taken of unprotected area in external wall of protected shaft

Diagram 2(b)(iii) – Pt. I Appendix B

- (iv) Unprotected area above 28m of uncomparted building



No account shall be taken of any unprotected area 28m or more above the ground in the external wall of building not divided into compartment

Diagram 2(b)(iv) – Pt. I Appendix B

## PART II

### Rules of calculation by reference to an enclosing rectangle

3. The conditions of this Part of this Appendix shall be satisfied if a building or compartment is so situated that no point on the relevant boundary is either between relevant plane of reference and the side of the building or compartment or at a distance from the relevant plane of reference which is less than the distance specified in the tables to Part of this Appendix, according to the purpose group of the building or compartment, the dimensions of the enclosing rectangle and the unprotected percentage.

4. For the purpose of this Part of this Appendix:

“relevant boundary” means as defined in Cl.1.2.52 and for the purpose of this calculation is either parallel to the side of the building under consideration or at an angle of not more than 80° with that side;

“plane of reference” means any vertical plane which touches the side or some part of the side of a building or compartment but which (however far extended) does not pass within the structure of such building or compartment (and for this purpose, any balcony, coping or similar projection shall be deemed not to be part either of that side or of the structure); and the relevant plane of reference shall in each case be taken as that most favourable in that respect to the person erecting the building;

“enclosing rectangle” means the smallest rectangle on the relevant plane of reference which would-

- (a) enclose all the outer edge of any unprotected area of the building or, if the building is divided into compartments, of the compartment (other than any of an unprotected area which is at an angle of more than 80° to the plane of reference the outer edges being for this purpose projected on the plane of reference by line perpendicular to such plane:
- (b) have two horizontal sides: &
- (c) have height and width falling within those listed in the tables to this Part of this Appendix:

“unprotected percentage” means the percentage of the area of the enclosing rectangle which is equal to the aggregate areas taken into account in calculating the enclosing rectangle and as projected on it.

## Determining the relevant boundaries





Diagram 4 – (1) Pt. II Appendix B

**Relevant boundaries** – where the side of a building is on the boundary, that is the 'relevant boundary'. Otherwise it is the actual boundary of the land either parallel to, or making an angle of not more than  $80^\circ$  with the face of the building in question. Note that a boundary can be relevant to more than one face. Where land abuts a road or canal the relevant boundary is taken as the centre of these. The points are illustrated in Cl.1.2.52 in Vol. 1 of the Handbook.






Diagram 4 – (2) Pt. II Appendix B

Plane of reference to more than one face of a building

Lines A – A, B – B & C – C represent the plane of reference.

**Plane of reference** – A plane of reference has to be established for each side of the building which faces a boundary. This is a vertical plane which touches, but does not pass through the building (except for such projections as bay

windows, balconies, cornies etc), nor does it cross the boundary (known as the "relevant boundary"). It must not make an angle of more than 80° with the side of the building.

It will usually (but not always) be appropriate for it to be parallel to the boundary and in many cases it will coincide with the face of the building. On to this all the unprotected areas facing the boundary are projected at right angles, but excluding any that are set at an angle of more than 80° to the plane. It is quite possible for a plane of reference to take in more than one side of a building.

Enclosing rectangle

A rectangle is constructed on the plane of references so as to enclose the outer limits of all the unprotected areas on that side of the building or compartment. The enclosing rectangle is the smallest rectangle which would :

- (a) enclose the outer edges of any unprotected areas;
- (b) have two horizontal sides; and
- (c) have height and width falling within those listed in Tables 1 and 2





Diagram 4 – (3) Pt.II Appendix B

Unprotected percentage

This is established by taking the aggregate area of all the unprotected areas (see diagram above) as percentage of the area of the enclosing rectangle.

## Example on calculations on unprotected areas

### **A** Example on calculations of unprotected openings/separation distance requirements for factory.



(b) Compartmented  
(assume compartmentation as shown)

Each storey is a compartment as shown in above diagram (compartments A & B). It is assumed that the relevant boundary is parallel with the face of the building. For calculating the unprotected areas, each compartment can be taken separately, usually the one with the most unprotected areas. As both compartments have the same unprotected openings, only one is taken for the calculations.

1. Assume a rectangle (to enclose all relevant unprotected areas) = 5.5m x 11m

2. The rectangle formed under (1) is to be converted to enclosing rectangle. Thus to use the nearest corresponding enclosing rectangle from Table 1, of Fire Code 2002, enclosing rectangle = 6m x 12m = 72sq m

3. Unprotected areas = 32sq m (2 x 2 x 8 nos) – not relevant openings under 2(b) of Appendix B to Cl.3.5 Pt 1 are excluded e.g. openings less than 0.1m<sup>2</sup> and located more than 1.5m from other unprotected opening; openings to protected shaft

4. Unprotected percentage (unprotected areas as percentage of enclosing rectangle)

$$= 32\text{sq.m as percentage of } 72\text{sq.m}$$

$$= 36\% \text{ use } 30\% \text{ column in Table 2 in page 58}$$



5. From Table 2 distance from boundary = 4m (minimum)

Footnote: Interpolation is permissible. By interpolating between 30% and 40%, it works out to be 4.6m.

TABLES TO PART II OF APPENDIX 'B' TO C1 3.5 - continued

**TABLE 2 - BUILDINGS OR COMPARTMENTS OF PURPOSE GROUPS V (SHOPS), VI (FACTORY) AND VII (STORAGE & GENERAL) - OPEN-SIDED CARPARKING DECKS SEE TABLE 1**

Width of enclosing rectangle in metres	Distance in metres from relevant boundary for unprotected percentage not exceeding								
	20	30	40	50	60	70	80	90	100
Enclosing rectangle 6 m high									
3	1.5	2.0	2.5	3.0	3.0	3.5	3.5	4.0	4.0
6	2.0	3.5	3.5	4.0	4.5	5.0	5.5	5.5	6.0
9	2.5	3.5	4.5	5.0	5.5	6.0	6.5	7.0	7.0
12	3.0	4.0	5.0	5.5	6.5	7.0	7.5	8.0	8.5
15	3.0	4.5	5.5	6.0	7.0	7.5	8.0	9.0	9.0
18	3.5	4.5	5.5	6.5	7.5	8.0	9.0	9.5	10.0
21	3.5	5.0	6.0	7.0	8.0	9.0	9.5	10.0	10.5
24	3.5	5.0	6.0	7.0	8.5	9.5	10.0	10.5	11.0
27	3.5	5.0	6.5	7.5	8.5	9.5	10.5	11.0	12.0
30	3.5	5.0	6.5	8.0	9.0	10.0	11.0	12.0	12.5
40	3.5	5.5	7.0	8.5	10.0	11.0	12.0	13.0	14.0
50	3.5	5.5	7.5	9.0	10.5	11.5	13.0	14.0	15.0
60	3.5	5.5	7.5	9.5	11.0	12.0	13.5	15.0	16.0
80	3.5	6.0	7.5	9.5	11.5	13.0	14.5	16.0	17.5
100	3.5	6.0	8.0	10.0	12.0	13.5	15.0	16.5	18.0
120	3.5	6.0	8.0	10.0	12.0	14.0	15.5	17.0	19.0
No limit	3.5	6.0	8.0	10.0	12.0	14.0	16.0	18.0	19.0

### 3.5.6 Buildings on land in common occupation

If two or more detached buildings are erected on land in common occupation, any external wall of any building so erected which faces an external wall of such other building, the relevant boundary shall be a notional boundary passing between those buildings and such boundary must be capable of being situated in such a position as to enable the external walls of those buildings to comply with the requirements of Cl.3.5.3.




Diagram 3.5.6

- (a) It is necessary to assume a notional boundary when two or more detached buildings are erected on land in common occupation.
- (b) The notional boundary is taken to exist in space between the buildings and is positioned so that the external walls of building A and B facing the notional boundary comply with the separation distance requirement in accordance with Tables of Appendix B, based on the percentage of unprotected area and the purpose group of the compartment/floor.
- (c) Unprotected openings shall be assessed for each building separately. The separation distance between the two buildings shall be not less than the sum of the distance each building would require to a relevant boundary ie. "a" is equal to or greater than the separation distance to the boundary for building A and "b" is equal to or greater than the separation distance to the relevant boundary for building B.

### 3.5.7 Vertical fire spread

For high and low parts of different compartments of a building abutting each other, either one of the following requirements shall be complied with to prevent spread of fire from the roof close to and lower than the external of the higher part:

- (a) The roof over the lower part of the building shall be fire rated in accordance with the element of structure for minimum 1 hour for a distance of 5m measured horizontally from the external wall of the higher part of the building; or
- (b) The external wall of the higher part of the building overlooking the roof below shall have the necessary fire resistance rating in accordance with the element of structures for minimum 1 hour for a vertical height of not less than 9m measured from the lower part of the building.
- (c) the above requirements shall not be applicable to buildings or lower parts of the building which are sprinkler protected, or old shophouses which are subject to URA's Conservation Programme or built before 1969 referred to under cl.1.1.1 and cl.1.1.2




Diagram 3.5.7(a)

A fire occurring in the 3<sup>rd</sup> storey would spread vertically to 4<sup>th</sup> storey via the roof and windows. To prevent the fire spread vertically, the roof of 3<sup>rd</sup> storey should be fire rated for min. 1 hour for a distance of 5m measured horizontally from the external wall of 4<sup>th</sup> storey abutting the roof of 3<sup>rd</sup> storey. The above requirement to fire rate the roof of 3<sup>rd</sup> storey will not be applicable if the building or lower part of the building is sprinklered protected.




Diagram 3.5.7(b) - 1




Diagram 3.5.7(b) - 2

Providing imperforate fire rated external wall is an alternative to fire rating the roof under subclause (a).

The above 2 diagrams show the 2 ways of preventing fire spread vertically from the lower floor to the upper floors.

However, if the buildings or lower part of the building are sprinkler protected, the above requirements are not applicable.

### 3.6 SEPARATING WALLS

#### 3.6.1 Requirement of separating walls

Every separating wall shall:

- (a) Form a complete vertical barrier in the same vertical plane through the full height between the buildings it separates, including roofs and basements and shall be imperforate except for provisions of openings permitted under Cl.3.6.2, and
- (b) Have the appropriate fire resistance to comply with the requirements of Cl.3.3, and
- (c) Be constructed of non-combustible materials, together with any beam and column which form part of the wall and any structure which it carries.
- (d) Not include glass fire resisting walls.




Diagram 3.6.1 – 1

Separating wall is the common wall that separates one unit from another. It is to prevent the spread of fire from unit to unit. The separating wall shall have the appropriate fire resistance rating as the elements of structure of the adjoining unit having the larger floor area or cubical extent as the case may be. Separating wall shall be imperforate, constructed of non-combustible materials and must have a fire resistance of not less than one hour. Openings may be formed for the passage of small pipes or where permitted as a means of escape under Cl.3.6.2. It shall not include fire resisting glass.

Separating wall applies to separating unit within the same warehouse complex/building. It shall also apply within tenanted area for factory/warehouse.




Diagram 3.6.1 - 2

With the separating wall brought above the roof, the concern of fire spread through cracks and gaps caused by poor bonding/fire stopping at wall/roof junction would be eliminated.

### 3.6.2 Openings in separating walls

A separating wall shall have no openings except for -

- (a) A door required to provide a means of escape in the event of a fire, having the same fire resistance as that required for the wall and complying with Cl. 3.9.2, or
- (b) A door provided for the purpose of public circulation and permitted by the Relevant Authority, having the same fire resistance as that required for the wall and complying with Cl. 3.9.2, or
- (c) Openings for the passage of a pipe complying with the relevant provisions of Cl. 3.9.3.

*Sub-clause (b) is not applicable to Purpose Group VI & VIII.*

- (a) *Door opening between 2 industrial units is not acceptable, unless the units are owned by one owner and occupied by a single company. In such a case the door opening in the separating wall shall be used solely for providing communication between the units and shall not be taken as means of escape during fire emergency, unless otherwise allowed.*

The owner is to furnish an undertaking to FSB that should one of the units be sold, the door opening in the separating wall shall be bricked-up to have the necessary fire resistance as the adjoining wall.

### 3.6.3 Separating wall - roof junction

A separating wall shall be either carried up to form a close joint with the underside of a pitched roof of non-combustible covering or carried up above the level of such roof covering. The junctions between such separating wall and roof shall be properly fire-stopped so as not to render ineffective the resistance of such separating to the effects of the spread of fire.




Diagram 3.6.3

Separating wall is carried right up above the roof coverings to act as a barrier to prevent fire spread over the roof level. The above clause addresses the concern at the junction of separating walls with roofs and other elements of structure to prevent fire from spreading through cracks and gaps at such junctions.

### 3.6.4 Separating walls-external wall junction

If any external wall is carried across the end of a separating wall, such external wall and separating wall shall be bonded together or the junction of such walls shall be fire-stopped to comply with the requirements of Cl.3.12






Diagram 3.6.4

### 3.6.5 Prohibition of combustible materials in separating walls

No combustible material shall be built into, carried through or carried across the ends of or carried over the top of separating walls in such a way as to render ineffective such separating walls to the effects of the spread of fire.




Diagram 3.6.5 - 1

Combustible materials built into separating wall would weaken the fire resistance integrity of the wall. Separating wall must be constructed of wholly non-combustible materials, including the beam, column or other structure carrying the wall. Exception is allowed for internal linings under Cl.3.13. However, for building under conservation, it would be acceptable if the original method of construction of floor is required to be retained.

### 3.7 COMPARTMENT WALLS AND COMPARTMENT FLOORS

#### 3.7.1 Requirements of compartment walls and compartment floors

Every compartment wall or compartment floor shall be required to -

- (a) Form a complete barrier to fire between the compartments it separates, and
- (b) Have the appropriate fire resistance to comply with the requirements of Cl.3.3, and
- (c) Be constructed of non-combustible materials (together with any beam or column which forms part of the wall or floor and any structure which it carries), and
- (d) Have no fire resisting glass forming part of it unless permitted under cl.3.15.13.  
(No illustration)

*Compartment walls and floors are to be totally imperforate except for the following permitted openings :*

- (a) doors*
- (b) protected shafts*
- (c) ventilation ducts*
- (d) pipes*
- (e) chutes eg. refuse, linen*

*Compartment walls and floors are to be constructed wholly of non-combustible materials, including any beam or column which forms part of the wall or floor and any structure which it carries. The walls and floors shall be constructed to have the necessary fire resistance of min. 1 hour to comply with the requirements of Cl.3.3. See also Cl.3.2.5 on the provision of compartment walls and floors. Provision of fire resisting glass in compartment wall or floor separating residential units is not allowed under Cl. 3.15.13, provided the building is sprinkler protected.*

#### 3.7.2 Openings in compartment wall or compartment floor

A compartment wall or compartment floor shall have no openings in it, except for -

- (a) A door which has the same fire resistance rating as the compartment wall and complies with the relevant requirements of Cl. 3.4, unless permitted by other provisions of the Code, or

- (b) A protected shaft which complies with the requirements of Cl. 3.8, or
- (c) The passage of a pipe or ventilation duct, such openings in the compartment wall or compartment floor shall be protected to comply with the relevant provisions of Cl. 3.9.

*It is common practice to provide ½ hour fire resistance entrance door to flat or maisonette from common space, eg lobby. The fundamental reasons are that entrance doors are subject to normal everyday usage and that it is generally accepted that no combustible materials would be placed behind the doors.*

*In other situation, the door within compartment wall shall have the same fire resistance as the compartment wall. This is applicable to trap doors in floors.*




Diagram 3.7.2(c)

Compartment walls and floors are required to be totally imperforate except for the abovementioned openings to permit movement of people, air, services etc in the building.

### 3.7.3 (a) Junction with other structures

Where a compartment wall or compartment floor forms a junction with any structure comprising any other compartment wall, or any external wall, separating wall or structure enclosing a protected shaft, such structures shall be bonded together at the junctions or the junctions shall be fire-stopped to comply with the requirements of Cl. 3.12.

### (b) Opening in curtain walling

The opening occurring at the junction between the edge of a structural floor and the curtain walling shall be sealed to prevent the spread of smoke and flame from the lower floor to the upper floor via the opening. Materials to be used for sealing the opening shall have the requisite fire resistance rating as the elements of structure.

See subclause 3.6.4 (Separating wall – external wall function)




Diagram 3.7.3(b)

### 3.7.4 Compartment wall – roof junctions

Where a compartment wall forms a junction with a roof, such compartment wall shall be carried up to form a close joint with the underside of the roof and shall be properly fire-stopped or shall be carried up above the level of the roof covering and the junction

between such compartment wall and roof shall be properly fire – stopped so as not to render ineffective the resistance of such compartment wall to the effects of the spread of fire.




Diagram 3.7.4

*Compartment wall shall be brought up to the underside of the roof coverings, including jack roof to complete the fire separation and to prevent fire spread from compartment to compartment. See also sub-clause 3.6.3 (separating wall – roof junction)*

### 3.7.5 Prohibition of combustible materials

No combustible material shall be built into, carried through or carried across the ends of any compartment wall or compartment floor or carried over the top of any compartment wall in such a manner as to render ineffective the resistance of such wall or floor to the effects of the spread of fire.

*See subclause 3.6.5 (Prohibition of combustible material in separating wall)*

### 3.7.6 Non-combustibility of compartment walls or floors

Every compartment wall or compartment floor shall be constructed of non-combustible materials, unless permitted by the Relevant Authority.

*Construction of compartment walls and floors is to be entirely of non-combustible material, except for compartment walls or floors in buildings which are required to be retained by URA under the conservation programme. There are also certain other exceptions :*

- a) floor finishes
- b) wall or ceiling linings complying with Cl.3.13
- c) suspended ceilings under Cl.3.3.6

*Any structural members carrying compartment walls or floors must also comply with the requirement of non-combustibility. Apart from the contribution made by suspended ceilings under CL.3.3.6, the fire resistance of the structural members must be attained without assistance from any combustible material (with the exception of buildings designated for conservation).*

### **3.8 PROTECTED SHAFTS**

#### **3.8.1 Purpose of protected shaft**

A protected shaft shall not be used for any purpose additional to those given as defined under Cl. 1.2.47.

All services such as, pipe/duct installation should not be located inside protected staircase. Likewise, no washroom is allowed to be located inside protected staircase.

(No illustration)

*The purposes of providing protected shaft are to delay or prevent the spread of fire between compartments through which staircases or other shafts pass directly and to enable people or things or air to pass between compartments. "Protected Shafts" include stairways, lift shafts, chutes, ducts or any other shaft enabling movement of people, goods, air, pipes, etc. Protecting structures shall be treated as elements of structure for the purpose of determining the period of fire resistance rating.*

#### **3.8.2 Requirements of protected shaft**

Every protected shaft shall be required to –

- (a) Form a complete barrier to fire between the different compartments which the shaft connects, and
- (b) Have the appropriate fire resistance to comply with the requirements of Cl. 3.3, and
- (c) Be constructed of non-combustible material (together with any beam or column which forms part of the enclosure and any structure which carries it).




Diagram 3.8.2

See Cl.1.2.48 under Definition (Volume 1)

Where the protection afforded to a compartment is penetrated to allow the movement of people, goods or anything else between compartments by means of eg. a staircase, lift or duct, the protection to the compartment must not be lowered or diminished. This is achieved by enclosing the means of transportation from one compartment to another in a protected shaft which is so constructed that any penetration of the enclosures to the shaft poses no direct or indirect threat to the compartments connected by the shaft. Hence, the terms "protected shaft" and "protecting structure" for the structure enclosing such a shaft. The elements enclosing the shaft (unless formed by adjacent external walls) are compartment walls and floors.

Figure (iii) of the above diagram illustrates a shaft which is enclosed by compartment or separating wall, external wall and internal walls called protecting structure. The fire resistance of the compartment or separating wall should be based on the size of the floor area or cubical extent of the adjoining larger compartment and shall not be less than 1 hour. The fire resistance of the external wall would be determined by the separation distance requirements under Cl.3.5. The external wall is not a protecting structure and could be fully unprotected areas having no fire resistance. The remaining 2 walls of the shaft are protecting structure which must be imperforate except for certain permitted openings, eg. inspection doors which need to have fire resistance equivalent to half that of the protecting structure.

*All protecting structure shall be constructed of non-combustible material except for surface linings which shall comply with Cl.3.13. The fire resistance of the protecting structures shall be that for the elements of structure of the building.*

### 3.8.3 Openings in protected shaft

A protected shaft shall have no openings in its enclosure, except-

- (a) In the case of any part of the enclosure which is formed by a separating wall, any opening which complies with the requirements of Cl.3.6 for separating walls, or
- (b) In the case of any part of the enclosure which is formed by a compartment wall or a compartment floor, any opening which complies with the requirements of Cl.3.7 for compartment wall or compartment floor, or
- (c) In the case of any part of the enclosure which is formed by the protecting structure –
  - (i) a door which has the appropriate fire resistance to comply with the requirements of Cl. 3.4 for test of fire resistance, or otherwise permitted by provision of Cl. 3.8.6, or
  - (ii) the passage of a pipe, excluding protecting structure to exit staircase and exit passageway, or
  - (iii) inlets to and outlets from and opening for the duct, if the shaft contains or serves as a ventilation duct,

such openings in the protected shaft shall be protected to comply with the relevant provisions of Cl. 3.9 for protection of openings.






Diagram 3.8.3 (a)




Diagram 3.8.3 (b)

Protected shaft bounded on three sides by protecting structure and fourth side by an external wall. Permitted opening to each unit shall be protected by a door of at least one half of the fire resistance rating of the enclosing wall, or half an hour, whichever is the greater. The aggregate fire resistance of the 2 doors shall not be less than the fire resistance of the protecting structure.

Permitted openings in protected shaft

a) Shaft containing ventilation duct pipes




Diagram 3.8.3(c) - 1

b) Shaft containing gas pipe





Diagram 3.8.3(c) - 2

c) Shaft containing a lift



d) Shaft containing exit staircase




Diagram 3.8.3(c) - 3

Fire resisting doors to comply with Cl.3.9.2 and shall have  $\frac{1}{2}$  hour fire resistance or half the resistance of the enclosing walls, whichever is the greater.

- 1) Any opening in compartment floor/wall would constitute a break in compartmentation. Therefore even small service pipes, strictly speaking must be enclosed in protected shaft.
- 2) However, clause 3.9 allows pipe size not greater than those sizes provided in Table 3.9A to be unprotected, provided the pipes are to be spaced at min. 50mm apart or half the diameter of the larger pipe, whichever is larger. This is to avoid clustering of pipes which would weaken the compartment floor or wall
- 3) Openings in compartment floors to accommodate staircases, lifts and services form a vertical shaft which can become a ready means of passage of fire from one storey to another, accentuated by the flue effect created by a fire.
- 4) Hence, protected shafts are needed to maintain the overall fire integrity of the building. However, these shafts need to have door openings for movement of people, eg. staircase, lifts and maintenance purposes in the case of shafts containing services. All the door openings to protected shaft are considered the sources of weakness in the integrity of the shafts and they must be protected.
- 5) Door openings  
Doors in protected shaft must have at least  $\frac{1}{2}$  hour fire resistance rating or half the fire resistance of the protecting structure whichever is greater.

- 6) Such a relaxation from the full standard of fire integrity is reasonable as it is expected that combustible materials would not be placed next to the door and that a fire has to break into the shaft and break out again at the upper level. Also if the top of the shaft is adequately ventilated, the tendency for lateral spread is considerably reduced.
- 7) The primary purpose of protecting structure is to provide the compartmentation between floors. As such the structure shall have full fire resistance as the elements of structure. The relaxation on fire resistance accorded to fire doors shall not be extended to the protecting structure ie. halve the fire resistance of the elements of structure. The main reason is that by halving the fire resistance of protecting structure, the threat of failure and collapse of the enclosing walls would be greater in times of fire emergency and should the walls collapse, large opening would be created in the shaft to permit the spread of fire and smoke, which is not acceptable. As to door openings in protected shaft, the eventual failure of the fire door is considered acceptable owing to the limited door opening size. See illustrations (c) and (d).
- 8) Ventilation ducts  
Ventilation ducts are usually constructed of sheet metal, which do not have fire resistance and therefore should a fire occur, they will quickly distort and collapse leaving a hole in any wall through which they pass. Conversely, a fire occurring in the duct could also cause collapse.
- 9) Therefore, where the duct penetrates the protected shaft, a fire damper should be fitted at the opening of the protecting structure. The fire damper shall be capable of sealing the opening in the protecting structure and be installed independently of the duct trunking. In this way, the fire damper would not be affected by collapse of duct work and be able to maintain the fire integrity of the shaft. See illustration (a).
- 10) Pipes  
Where pipes are contained within a protected shaft, the problem of maintaining the integrity of the fire compartment is made simple, irrespective whether the pipes are made of UPVC or combustible materials. However, for gas pipes or pipes containing combustible liquids, they shall be located in separate shafts.
- 11) The construction of gas pipes shaft is different from other shafts owing to the need to provide through or external ventilation. Gas pipe shaft shall comply fully with SS CP 51. See illustration (b).
- 12) General  
In order to maintain the level of integrity of protected shafts, openings in protected shafts shall be restricted to the following :
- a) Openings for pipe
  - b) Door openings to lift shaft, staircase
  - c) Openings for ventilation ducts
  - d) Access openings for electrical cables shaft
  - e) Openings for chutes, linen or refuse.

### 3.8.4 Non-combustility of protecting structures

Every protecting structure shall be constructed wholly of non-combustible materials except that floor, wall and ceiling finishes which do not contribute to the fire resistance of such protecting structure may not be required to comply with the requirements for non-combustibility.

(No illustration)

*The requirement that all protecting structure shall be constructed of non-combustible materials is also spelled out under Cl.3.8.2. As to the provision of combustible finishes to floor, wall and ceiling, it must be observed that such provision will not be permitted inside protected shafts that are used for the passage of people such as exit staircases, exit passageways and smoke-stop lobbies under Cl.3.10.4 and Cl.3.13.6.*

### 3.8.5 Ventilation of protected shaft

Ventilation of protected shaft shall comply with the following:

- (a) A protected shaft used for the passage of people, such as exit staircases, shall be ventilated to comply with the relevant provisions of the Code.
- (b) A protected shaft containing a pipe conveying gas shall be adequately ventilated directly to the outside air or other modes of ventilation allowed under SS CP 51.

(No illustration)

*Protected shaft used for passage of people, such as exit staircases shall be provided with adequate natural ventilation by fixed openings in the external walls. Such openings shall have an area of not less than 10 per cent of the floor area per floor of the staircase. Alternatively, the staircase can be mechanically ventilated under Cl.2.3.3(f). However, for internal exit staircase serving more than 4 storeys, the supply air shall be mechanically conveyed via a vertical duct extending through the staircase height and discharging from outlets distributed at alternate floor. Where the internal exit staircase exceeds 24m in height without provision for natural ventilation, the staircase shall be pressurised in accordance with Cl.2.3.3(g).*

*The mechanical ventilation system to internal staircase serving more than 4 storey and the pressurization system to internal exit staircase exceeding 24m shall be connected to emergency power supply. In addition, a remote manual start-stop switch shall be make available to fire fighters at the fire command centre, or at the fire indicating board where there is no fire command centre. The start-stop switch provides the fire fighter a quick means to shut-off the fans should it be detected*

that smoke had been drawn into the staircase by the fresh air supply fan.

A protected shaft conveying piped flammable gas should be adequately ventilated directly to the outside air by ventilation openings at high and low level in the shaft or comply with the modes of ventilation allowed in CP51. All gas pipe installations shall be vetted and approved by acceptable organisation (example: Powergas) before any works can be carried out on site.

### 3.8.6 Doors in protecting structures

Any door fitted to an opening in protecting structure shall have fire resistance for not less than half the period required by other provisions of the Code for the protecting structure surrounding the opening.

Exception :

Any door fitted to an opening in protecting structure of a shaft containing services such as electrical cables, pipes, ducts would not need to have the fire resistance rating if the door is located along the wall facing the external corridor.




Diagram 3.8.6

As the doors in the electrical and pipe shafts are opening into an external corridor which is naturally ventilated, there is no need to fire rate the doors

Protected shaft A serves 2 compartments. Compartment A could be a common area eg. lounge and compartment B in factory/warehouse unit.

Door A1 is opening in the direction of exit travel, whereas door A2 is the entrance door of the factory/warehouse unit, which swings inward. The number of exit door openings in a protected shaft containing an exit staircase shall not exceed two per floor. This is to prevent additional openings from weakening the integrity of the protecting structure.

The aggregate fire resistance of door A1 and A2 shall not be less than the compartment wall or the protecting structures to the shaft. This is to ensure that the fire resistance between compartment A and B is not reduced at the door openings.

*Door A1 can be held in the open position provided it is fitted with electro-magnetic or electro-mechanical device. See Cl.1.2.20 in Volume I.*

*All doors in shaft A & B shall have the fire resistance rating of half that of the enclosing protecting structures to the shafts, but shall never be less than half hour. See also Cl. 3.8.3 for further explanation.*

### 3.8.7 Protected shaft containing exit staircase

A protected shaft which contains an exit staircase shall comply with the following:

- (a) It shall not contain any pipe conveying gas or combustible liquid.
- (b) It shall not contain any services that are not solely serving the same exit staircase except for:
  - (i) cut-off sprinkler and pipe for that staircase; and
  - (ii) UPVC or cast iron rain water downpipes serving the roof directly above the exit staircase, and not routed through anywhere outside the staircase.
- 3.8.7 (c) The protecting structure shall be constructed of masonry, or drywall. If drywall construction is used, the following conditions shall be complied with :
  - (i) Drywall shall be non-combustible; and
  - (ii) Drywall shall have fire resistance for not less than the relevant period specified in Table 3.3A having regard to the purpose group of the building of which it forms a part and the dimension specified in that Table; and
  - (iii) Drywall shall meet the criteria, in terms of impact and deflection performance, when subject to the tests of BS 5588 Pt 5 Appendix A and BS 5234 Pt 2; and
  - (iv) Drywall shall meet the criteria, in terms of water absorption and bending strength performance, when subject to the test of BS 1230 Pt 1 (for gypsum plaster board) or ISO 1896 (for calcium silicate or cement board); and

- (v) The building shall have at least two independent exit staircase shafts (scissors staircases are considered as single shaft).




Diagram 3.8.7(c)(v)-1

*Building designed with single exit staircase shall have the protecting structure constructed of masonry, which is more solid and stable than fire rated dry walls. The main concern is that if the protecting structure, which is constructed of dry wall is damaged, smoke and heat would get into the staircase to affect the evacuees making their way down. Single Exit Staircase shall have its protected structure constructed of masonry.*



Diagram 3.8.7(c)(v)-2

Where two independent staircases are provided, the protecting structure to each of the staircase can be constructed of drywall.






Diagram 3.8.7(c)(v)-3

Where a building is designed with a pair of scissors staircases to meet the provision of exit requirements, the scissors staircases shall be considered as within a common shaft if drywall is used for the construction of the protecting structure. The main reason is that if one of the shaft is damaged, the other shaft is likely to be affected, thereby causing smoke to get into both staircases. This would render the pair of scissors staircases inaccessible. In addition, the drywall enclosures are prone to other damages, thus affecting the effectiveness and integrity of the protected shafts. However, for the purpose of exit computation, the pair of scissors staircases shall literally be taken as 2 staircases though it could only qualify as a single shaft.




Diagram 3.8.7(c)-1

Non-combustible steel studs, insulation materials and fire rated boards shall be used for the construction of drywall.




Diagram 3.8.7(c)-2

An exit staircase designated as fire fighting staircase in a building which exceeds 24m in habitable height has to be complemented by fire lift and fire fighting lobby. Separate ventilation shafts are required to be provided for the staircase and fire fighting lobby.

Exit staircases serving any building irrespective of the height, shall be devoid of combustible wall, floor and ceiling finishes. Building services which are not solely serving the exit staircase shall not be allowed to be routed through or inside the staircase. This is to prevent any possibilities of a fire occurring inside the staircase and the spread of fire into the staircase via the services such as electrical cables, ducts, combustible pipes, etc. Clause 6.2.2 of the Fire Code allows vertical stack of rising main and landing valve to be located inside the staircase as a last resort where smoke-stop lobby and common area outside the staircase are not available. Clause 2.4.3 of SS CP 10 allows sub-alarm panels to be located in the exit staircase provided there is no fire lift lobby or smoke-stop lobby in the building. The fire alarm cables shall be in metal conduit or trunking. This relaxation shall not apply to buildings which are more than 4 storeys in height where provision of smoke-stop lobby is a requirement.

The exit staircases are the means of escape in fire emergencies. All occupants must use the staircases to evacuate safely from any storey level to the final exits at ground level. The time taken to descend a staircase in a high-rise buildings could be more than an hour. With the staircase fully packed with evacuating occupants during an emergency, the staircase must be maintained safe from smoke, heat and fire throughout the fire resistance period of the enclosing protecting structures to the staircase. In view of the above and to prevent any mechanical damage, masonry construction to the protecting structure is usually preferred. An exception is allowed under Cl.3.8.9(d) for maximum 4 storey residential building where services are allowed to be located inside the staircase enclosure.

### 3.8.8 Lift shaft

A protected shaft which contains a lift shall comply with the following:

- (a) It shall not contain any pipe conveying gas or combustible liquid, other than those in the mechanism of a hydraulic lift.
- (b) The protecting structure shall be constructed of masonry, or drywall. If drywall construction is used, the following conditions shall be complied with :
  - (i) Drywall shall be non-combustible; and
  - (ii) Drywall shall have fire resistance for not less than the relevant period specified in Table 3.3A having regard to the purpose group of the building of which it forms a part and the dimension specified in that Table; and
  - (iii) Drywall shall meet the criteria, in terms of impact and deflection performance, when subject to the tests of BS 5588 Pt 5 Appendix A and BS 5234 Pt 2; and
  - (iv) Drywall shall meet the criteria, in terms of water absorption and bending strength performance, when subject to the test of BS 1230 Pt 1 (for gypsum plaster board) or ISO 1896 (for calcium silicate or cement board); and
  - (v) Drywall shall meet the criteria of Cyclic Loading and Dynamic test as specified under Cl. 3.3 of Building Code of Australia Specification C 1.8.




Diagram 3.8.8(a) & (b) - 1

Lift shaft which is not located at the edge of atrium floors or at the external wall outside the building shall be constructed of masonry or drywall, provided requirements under 3.8.8(b) are fully complied with.

Sub-clause (a) above specifically permits combustible liquid in the mechanism of hydraulic lift. The liquid is concealed in vessels and forms part of the mechanical system to permit the homing of the lift during an emergency. The liquid has a high flash point of over 400°C.

### 3.8.8(c) Factory

Where a lift is either located at the edge of atrium floors or at the external wall and outside the building, the lift shall be considered as not enclosed within a protected shaft.

### Storage

Where a lift is located at the external wall and outside the building, the lift shall be considered as not enclosed within a protected shaft.




Diagram 3.8.8(c) - 1

*In the above diagram the lift is unenclosed, being located within the atrium void. There is no penetration of any compartment floor and smoke migration caused by the 'piston-effect' of lift movement is no longer a concern. Smoke from a fire in any occupancy floor will flow from the ceiling layer into the atrium void where it will tend to rise upwards due to its natural buoyancy. A smoke control system would eventually extract the smoke out of the building*




Diagram 3.8.8(c) - 2

The lift is sited outside the external wall of the building. There is no concern of smoke and heat being transferred from floor to floor. Hence it is not required to be enclosed in a protected shaft. This type of lift is commonly known as 'bubble lift' or 'sky lift'.




Diagram 3.8.8(c) - 3

The above diagram shows that the lift is located away from the atrium void. As the lift punctures through the compartment floors, it must be enclosed in a protected shaft to prevent the spread of smoke and heat from floor to floor.

- (d) The protected shaft shall be vented in accordance with SS CP 2 Code of Practice for Installation, Operation and Maintenance of Electric Passenger and Goods Lifts. The vents shall be so arranged as to induce exhaust ventilation of the shaft. Where vents could not be provided because of the location of the lift shaft, ventilation duct protected by drywall complying with Cl.3.8.8(b) serving as ventilation of the shaft may be provided instead. If the duct is not to be fire rated, fire dampers shall be provided to the duct at the wall of the lift shaft, provided such relaxation shall not apply to shaft containing fire lift.
- (e) Openings for the passage of lift cables into the lift motor room located above or at the bottom of the shaft shall be as small as practicable.
- (f) Transom panel above lift entrance shall be considered as part of the protecting structure and shall therefore conform to the fire resistance requirements of the protected structure.




Diagram 3.8.8(e)

*Floor indicator panel should be surface mounted. If it is built into the transom panel, care should be taken to ensure that the fire resistance of the panel is not lowered. It is a common mistake to puncture the transom panel to receive the floor indicator panel without giving consideration to the fire integrity of the panel. Such practice contravenes the above requirement, as Cl.3.8.2 requires that the protecting structure, including the transom panel, forms a complete barrier and should have the appropriate fire resistance rating.*

- 3.8.8 (g) If it serves any basement storey and not adjoining any void connecting to upper levels or any external spaces, there shall be provided a lobby enclosed by walls having fire resistance of not less than 1 hour and fire door of not less than half an hour.




Diagram 3.8.8(f) - 1

Lift opening into basement and not adjoining a void that opens to the sky or any external spaces, shall be provided within a smoke stop lobby having 1-hour fire rated enclosures and ½ hour fire door.

The smoke-stop lobby acts as a buffer zone to prevent smoke from being drawn into the lift shaft through the 'piston-effect' of the movement of the lift.




Diagram 3.8.8(f) - 2

Lift opening into basement storey and adjoining a void opening to the sky or any external spaces does not require a smoke-stop lobby. Smoke occurring in the vicinity of the lift would be drawn into the void and vented upward into the open space. This provision would help to reduce the chance of smoke being sucked into the lift shaft.



### 3.8.9

#### Protected shaft containing other services installations

A protected shaft used for the enclosure of services shall comply with the following:

- (a) The protecting structure for protected shaft containing kitchen exhaust ducts and mechanical ventilation ducts serving areas specified in Cl.5.2.1(g)(i) to (iii) and (h) which pass through one or more floor slabs shall be of masonry or drywall. Such shaft shall be completely compartmented from the rest of the shaft space containing other ducts or any other services installations. Protected shaft containing ducts serving other areas which pass through two or more floor slabs shall be constructed of drywall. If the protecting structure for the protected shaft is constructed of drywall, the following conditions shall be complied with:
  - (i) Drywall shall be non-combustible; and
  - (ii) Drywall shall have fire resistance for not less than the relevant period specified in Table 3.3A having regard to the purpose group of the building of which it forms a part and the dimension specified in that Table; and
  - (iii) Drywall shall meet the criteria, in terms of impact and deflection performance, when subject to the tests of BS 5588 Pt 5 Appendix A and BS 5234 Pt 2; and
  - (iv) Drywall shall meet the criteria, in terms of water absorption and bending strength; and performance, when subject to the test of BS 1230 Pt 1 (for gypsum plaster board) or ISO 1896 (for calcium silicate or cement board).

*The protecting structure for protected shaft containing kitchen exhaust duct and mechanical ventilation ducts which pass through one or more floors and serving areas such as:*

- (i) exit staircases and exit passageways*
- (ii) Smoke-stop and fire fighting lobby*
- (iii) Areas of refuge within the same building*

- (iv) Emergency generator
- (v) Engine driven fire pump

shall be constructed in masonry or dry wall. Each shaft shall be separately compartmented from one another. Protected shaft containing ducts serving other areas not mentioned above and which pass through two or more floors can be constructed of fire rated materials, instead of masonry.

(i)




Diagram 3.8.9(a) – 1

Eg. kitchen exhaust duct shall be in a separate compartment from that for a mechanical ventilation duct. Kitchen exhaust ducts serving different kitchens shall be in separate shafts. Mechanical ventilation duct serving the area of refuge shall be in different shaft from that serving the pump room. The main reason for separate shafts is to prevent smoke and fire spread from shaft to shaft.

(ii)





Diagram 3.8.9(a) - 2

Kitchen exhaust shaft for each kitchen is completely separated. The horizontal run of the exhaust from kitchen 1 is protected with fire rated material.


(iii)

a. Flue passing through compartment wall or floor



Flue walls should have a fire resistance of at least one half of that required for the compartment wall or floor, and be of non-combustible construction

b. Flue built into compartment wall



In each case flue walls should have a fire resistance of at least one half of that required for the compartment wall and be of non-combustible construction

Diagram 3.8.9(a) - 3

If a flue, or duct containing flues or appliance ventilation duct(s), passes through a compartment wall or compartment floor, or is built into a compartment wall, each wall of the flue or duct should have a fire resistance of at least half that of the wall or floor in order to prevent the by-passing of the compartmentation.

- 3.8.9 (b) Protected shaft used for the enclosure of electrical power services shall be interrupted at every floor level with barriers with fire resistance of at least half an hour. Protected shaft used for the enclosure of telecommunications cables shall be interrupted by barriers with fire resistance of at least half an hour at vertical intervals not exceeding 15m. Such cavity barriers shall comply with the relevant provision of Cl.3.11.

(i)




Diagram 3.8.9(b) – (i)

Protected shaft containing electrical cables shall be interrupted at every floor with cavity barrier having min.  $\frac{1}{2}$  hour fire rating to prevent vertical spread of fire and smoke. The main concern is that cables are a source of fuel and ignition. The presence of fire stopping at every floor would help to confine fire to a single storey or segment of the shaft.

(ii) Protected shaft containing Telecom cables

Protected shaft used for the enclosure of telecommunications cables shall be interrupted by barriers with fire resistance of at least half an hour at vertical intervals not exceeding 15 m. Such cavity barriers shall comply with the relevant provisions of Cl. 3.11.




Diagram 3.8.9(b) – (ii)

Protected shaft containing telecommunications cables including cable TV lines is provided with cavity barrier at vertical intervals not exceeding 15m or 3 storey whichever is the shorter. The cables are mainly of low voltage and hence of a lower risk when compared to electrical cables.

### 3.8.9 (c) Omission of self-closing devices

In the case of protected shafts which are interrupted by barriers with fire resistance of at least half an hour at every floor level or protected shafts containing sanitary pipes or water pipes, fire resisting doors opening into the protected shaft are not required to be installed with automatic self-closing devices, provided such doors are kept closed and locked at all times.




Diagram 3.8.9(c)

Provision of self-closing device for the inspection door of a protected shaft, which is interrupted by barriers having  $\frac{1}{2}$ -hour fire resistance at every floor, is not required, if the door is kept closed and locked at all times. The above relaxation is also applicable to TAS shafts, provided they are interrupted by barriers with fire resistance of at least  $\frac{1}{2}$ -hour at every floor level.

An important point to note is the depth of the shaft which shall not exceed 750mm. If it exceeds 750mm, the shaft would be considered as a room and provision of self-closing device for the fire door becomes a necessity.

The above relaxation is based on the understanding that it is unlikely that a shaft would be converted to a store if its depth is less than 750mm and that the door would normally be kept in the locked position when workmen are not carrying out servicing work. Also, maintaining the door in the closed or locked position at all times is the responsibility of the management corporation of the estate.

- 3.8.9 (d) All protected shafts containing services shall not be located within an exit staircase.




Diagram 3.8.9(d) - 1

A factory or warehouse building which does not require the provision of smoke stop lobby to exit staircase by virtue of its height shall be required to comply fully with the above requirement. All protected shafts containing services are located in a common lobby adjoining the exit staircase.




Diagram 3.8.9(d) - 2

Although the services are enclosed in protected shafts, they are not permitted to be located in exit staircase. The main reasons are :

- a) Within the protected shaft, the combustible materials eg. Cables PVC pipes are a source of fire risk. A fire could originate from these combustible materials and spread in the exit staircase enclosure.

Exit staircase is a dedicated route for escape of occupants, services which are not serving the staircase shall not be located inside the enclosure.

### 3.9 PROTECTION OF OPENINGS

#### 3.9.1 Application

The provisions of this Clause are made in connection with the protection of openings permitted in elements of structure or other forms of fire resisting construction required to act as a barrier to fire and smoke.

(No illustration)

*For functional purposes, openings in compartment walls, floor etc are required in buildings to allow movement of people and the installation of services such as pipes, ventilation ducts etc. To prevent the spread of fire and smoke, such openings shall be appropriately protected.*

#### 3.9.2 Fire doors

Fire doors for protection of openings shall comply with the following:

- (a) Fire resisting doors shall have the appropriate fire resistance as required by relevant parts of the Code, and two fire resisting doors may be fitted in an opening if each door by itself is capable of closing the opening and the two doors together achieve the required level of fire resistance, and




Diagram 3.9.2(a) – 1

*The two 1-hour fire door arrangement is deemed to satisfy compartmentation and equivalent to the fire resistance rating of the compartment wall (2 hours).*






Diagram 3.9.2(a) - 2

The provision of fire doors shown in the above diagram usually occur in separating walls, compartments or protecting structures.

- (b) All fire doors shall be fitted with an automatic self-closing device which is capable of closing the door from any angle and against any latch fitted to the door, and

(No illustration)

*All fire doors are required to be fitted with an automatic self-closing device, which shall not include rising butt. Self-closing device is not required to be fitted to doors of protected shafts having a depth of not more than 750mm under sub-clause 3.8.9(c).*

*Fire resisting door to exit openings of factory/warehouse units, protected staircases, protected lobbies, exit passageway, compartment walls etc. shall have minimum half-hour fire resistance. Doors to exit facilities shall not be fitted with any locking device. However, doors to exit openings of factory/warehouse units would be fitted with locking devices for security reasons. As fire door is to protect the openings in exit facilities, it should always remain in the closed position to prevent the spread of smoke and heat. The main function of the self-closing device is to return the door to its closed position after being opened for movement of occupants, goods etc. The passage latch fitted to the door is to hold the fire door in closed position to counteract the pressure differential across the door opening in a fire situation.*

*Buildings may have card key access or automatic-locking devices fitted to doors of exit staircases to prevent unauthorised access by outsiders.*

To gain entry into the staircase or to exit from it into any floor, the occupants need to key in a code number or use a card key access to unlock or release the locking device to the door. In times of power failure or activation of fire alarm system, the locking device would be unlocked automatically and all the exit doors could be opened manually. Prior approval should be obtained from SCDF "FSSD" before any door to exit facilities is fitted with any form of locking device.

When the door to the exit facilities consists of double leaves or multiple leaves, all the leaves shall be fitted with self-closing device and sequential closer or also known as door selector.

Self-closing device to fire door shall be properly maintained regularly. Faulty device shall be repaired immediately to prevent fire door being left in the open position.

(c) Where a self-closing device would be considered a hindrance to the normal use of the building, fire resisting doors may be held open as follows :

- (i) by a fusible link, or
- (ii) if the doors can be opened manually, by electromagnetic or electro-mechanical devices which can be activated by the presence of smoke and/or the building alarm system,

*(See illustration in Cl.1.2.20 under Definition in Volume I)*

(d) Any hinge on which a fire resisting door is hung shall be made entirely of non-combustible materials having a melting point of at least 800<sup>o</sup> C , and

(No illustration)

3.9.2 (e) Any fire door fitted in an opening which is provided as a means of escape:

- (i) shall be capable of being opened manually, without the use of key, tool, special knowledge or effort for operation from the inside of the building; and
- (ii) shall not be held open by any means other than by an electromagnetic or electro- mechanical device which can be activated by the presence of smoke and/or the building alarm system, provided that this shall not apply in the case of fire

doors opening into pressurised exit staircases.

- (iii) shall open in the direction of exit travel in accordance with Cl. 2.3.9.

*(See illustration in Cl.1.2.20 under Definition in Volume 1)*

- 3.9.2 (f) Fire doors where required to be provided shall be constructed and installed to comply with specifications stipulated under SS 332 Specification for Fire Doors.




Diagram 3.9.2(f)

All fire doors are required to bear PSB label and listed under the Product Listing Scheme of Productivity and Standards Board. It is important to note that fire door opening into pressurised exit staircases shall not be fitted with electromagnetic or electro-mechanical device. This is to ensure that the integrity of the pressurised exit staircase is maintained at all times.

### 3.9.3 Pipes

- (a) Pipes which pass through a separating wall, compartment wall or compartment floor shall be kept as small as possible and fire-stopped around the pipe. The nominal internal diameter of the pipe shall be not more than the relevant dimension given in Table 3.9A. Spacing between pipes shall be minimum 50mm or  $\frac{1}{2}$ -diameter of the largest pipe, whichever is larger.




Diagram 3.9.3 - 1

*The clustering of pipes without proper spacing would further weaken the integrity of the fire resisting walls in times of fire emergency.*

## Penetration of elements of structure by pipes




Diagram 3.9.3 - 2

## UPVC pipes located in external corridor




Diagram 3.9.3 - 3

*External corridor would be well ventilated. Hence lower fire risk is lower and the threat of spread of fire and smoke from floor to floor is very much reduced.*

(b) (i) Routing of gas pipes in basements

All gas pipes that are routed in basement shall be API pipes with welded joints. These joints shall be 100% radiography checked in accordance with sub-clause 3.4.2 (h) of SS CP 51. The gas pipes are not required to be fire rated if they are running outside essential areas such as exit staircases, smoke stop or fire fighting lobby, fire pump room, generator room, fire command centre, etc. If they run into the essential area, they are required to be encased in masonry.

(ii) For mechanically ventilated basement, the gas pipes shall be provided with pipe sleeves for the venting of gas pipes. One end of the sleeve shall be exposed to the external as specified in sub-clause 3.4.2 (g) of SS CP 51.

(iii) For naturally ventilated basement that complies with sub-clause 6.4.1(d)(iii)(b), the provision of pipe sleeve is not required

(No illustration)

3.9.4 Ventilation ducts

Ventilation duct which passes directly through a compartment wall or compartment floor shall comply with the following -

(a) Where the ventilation duct does not form a protected shaft or is not contained within a protecting structure,

(i) the duct shall be fitted with a fire damper where it passes through the compartment wall or compartment floor, and

(ii) the opening for the duct shall be kept as small as practicable and any gap around the fire damper shall be fire-stopped.




Diagram 3.9.4(a)

Proper fire stopping around the duct where it penetrates the compartment floor/wall and provision of fire damper at the compartment wall/floor would help to prevent fire and smoke spread from compartment to compartment.

- (b) Where the ventilation duct forms a protected shaft or is contained within a protecting structure, the duct shall be -
  - (i) fitted with fire dampers at the inlets to the shaft and outlets from it, and
  - (ii) constructed and lined with materials in accordance with the requirements in Chapter 7.





Diagram 3.9.4(b)

*The provision of fire damper at the entry to the protected shaft would help to complete the compartmentation to prevent fire or smoke from being drawn into the protected shaft via ventilation duct.*

- (c) The installation of ventilation ducts and fire dampers shall comply with the requirements in Chapter 7.

### 3.9.5 Flues

Duct encasing one or more flue pipes which passes through a compartment wall or compartment floor shall be of non-combustible construction having fire resistance of not less than half the minimum period of fire resistance required for the compartment wall or compartment floor through which it passes, except for kitchen flue pipes when the fire resistance shall be as required for the compartment wall or compartment floor.



Drawing 3.9.5 - 1

*Separate kitchen exhaust shaft enclosed in masonry or dry wall construction shall be provided for Kitchen (1) and (2). This is to prevent fire and smoke from spreading from one compartment to another. The wall enclosing the shaft shall have the same fire resistance as the compartment wall or floor.*

### 3.9.6 Service pipings and ductings

Air ducts, sanitary pipings, gas pipes and other services that are likely to permit the passage of flame or smoke in the event of a fire shall not be permitted to pass through rooms housing fire pump, emergency generator or fans handling smoke control system except where such services are required for the operation of these equipment.

(No illustration)



### 3.10 EXIT STAIRCASES

#### 3.10.1 Non-combustibility of structure

Every exit staircase, including the treads/risers and landing, shall be constructed of non-combustible materials.

(No illustration)

#### 3.10.2 Structure separating exit staircase

The exit staircase shall be separated from other parts of the building by a masonry structure or drywall complying with Cl.3.8.7(c) which shall have fire resistance for not less than the period required by Cl.3.3 for Elements of Structure.

#### 3.10.3 Exit Doors

Doors opening into the exit staircase shall have fire resistance of at least half an hour and fitted with automatic self-closing device.

#### 3.10.4 Finishes

Finishes to the ceiling/walls and floors of exit staircase shall be of non-combustible materials.

Internal exit staircase




Diagram 3.10.4

The protecting structure, excluding the external wall, to the staircase shall be constructed of masonry. Ceiling/wall and floor finishes shall be of non-combustible materials to ensure that the level of safety in the staircase is maintained at all times. The only exception allowed is the handrail material.

### 3.11 CONCEALED SPACES

#### 3.11.1 General Provision

Concealed spaces in a building shall be interrupted by construction of cavity barrier to restrict the spread of smoke and flames.




Diagram 3.11.1 - 1




Diagram 3.11.1 - 2

Concealed spaces or cavities in building provide a ready route or flue for smoke and flame to spread undetected for quite some time, thus increasing the risk to life safety of occupants in the building. This is particularly so in the case of void spaces above a suspended ceiling or in a roof space or in a raised floor system. Provisions are available in the Fire Code to reduce the risk of concealed smoke and flame spread by the introduction of cavity barrier when the area or linear dimensions of cavities exceed the limits as per Table 3.11A. Cavity barriers shall be constructed of non-combustible materials and shall have at least half hour fire resistance.

### 3.11.2 Closing the edges of cavities

Cavity barriers shall be used to close the edges of cavities, edges around openings through a wall, floor and any other part of the construction which contains a cavity and to separate any cavity in a wall, floor or any other part of the construction from any other such cavity.




Diagram 3.11.2

“Cavity barrier” means any construction provided to close a cavity against, or restrict the spread of smoke and flame within it.

In figure (I) above, cavity barriers are used to close the edges around the window opening. Similar application is provided to window in external cavity wall in figure (ii).

### 3.11.3 Interrupting cavities

Cavities including roof spaces shall be interrupted by cavity barriers where a wall, floor, ceiling, roof or other part of the construction abut the cavity, if there is provision for the element of structure to form a fire resisting barrier. Such cavity barriers shall be of fire resisting construction at least equal to the provision for that required for the fire resisting barrier.

Figure (i)




Diagram 3.11.3 – (i)

*Cavities must be closed where the fire barrier elements (compartment walls) abut the cavity (including the frame of a door).*

Figure (ii)




Diagram 3.11.3 – (ii)

Figure (iii)




Diagram 3.11.3 - (iii)

Any cavity within an element, or at the junction of two elements, must be closed by a cavity barrier

Figure (iv)




Diagram 3.11.3-(vi)

It is a common practice to bring the compartment wall right-up to the underside of the structural slab above. The cavity barrier above the compartment wall shall be treated as an extension of the compartment wall below.

Figure (v)




Diagram 3.11.3 – (v)

The roof space over a protected staircase must be separated by either a cavity barrier at (a) having the same fire rating as the wall of the staircase below, or a fire rated ceiling at (b). See Cl.1.2.8 under Definitions, Vol. 1 for further illustration. Extending the masonry wall right up to the underside of

*the roof coverings at (a) would meet the requirement under Cl.3.10 of having masonry enclosure to exit staircase.*

### 3.11.4 Sub-division of extensive cavities

Cavities, including roof spaces, unless otherwise permitted, shall be sub-divided so that the maximum distance between cavity barriers shall not exceed the relevant dimensions given under Table 3.11A.

TABLE 3.11A MAXIMUM DIMENSIONS OF CAVITIES

Location of cavity	Purpose Group of building or compartment	*Class of surface exposed in cavity	Max. dimension in any direction
Between roof and ceiling	I & II	any	no limit
	others	any	20m
Any other cavity	any	Class 0	20m
	any	any	8m
* excluding surface of any pipe, cable, conduit or insulation of any pipe.			

*The main reason of limiting the dimension of cavities is to prevent fire or smoke from spreading widely in large concealed space.*

### 3.11.5 Fire resistance and fixing of cavity barriers

Cavity barriers shall be

- (a) Constructed to provide at least half an hour fire resistance, and
- (b) Tightly fitted to rigid construction or the junctions shall be fire stopped to comply with the requirements of Cl. 3.12.




Diagram 3.11.5 - 1

Cavity barriers must be tightly fitted to rigid construction and mechanically fixed in position wherever possible. Where this is not possible (for example, in the case of a junction with slates tiles, corrugated sheeting or similar materials) the junction should be fire-stopped to prevent the spread of fire and smoke in the concealed space.

Cavity barriers must also be fixed so that performance will not be made ineffective by:

- (a) Movement of the building due to subsidence, shrinkage or temperature change; and
- (b) collapse in fire of any services penetrating them; and
- (c) failure in fire of fixings; and
- (d) failure in fire of any material or construction which they may abut. For example, if a suspended ceiling is continued over the top of a fire-resisting wall or partition, and direct connection is made between the ceiling and the cavity barrier above the line of the wall or partition, premature failure of the cavity barrier can occur when the ceiling collapses. However, this does not arise if the ceiling is designed to provide fire protection of 30 minutes or more.






Diagram 3.11.5 - 2

Compartment walls should be carried right up to the full storey height, to a compartment floor above or to the roof coverings, as appropriate. The walls in the ceiling above the common corridor shall not be treated as cavity barriers. They shall be treated as extension of the compartment walls below.

The main purposes of extending the compartment walls into the ceiling space are to complete the compartmentation to each apartment unit and to prevent smoke and fire spread via the concealed ceiling space.

### 3.11.6 Openings in cavity barriers

A cavity barrier shall have no opening in it except for:

- (a) A door which has at least half an hour fire resistance and shall be kept closed all time,
- (b) A pipe which complies with the provision under Cl. 3.9.3,
- (c) A cable or conduit containing one or more cables,
- (d) An opening fitted with suitably mounted automatic fire damper, and
- (e) A duct which is fitted with a suitably mounted fire damper where it passes through the cavity barrier.




Diagram 3.11.6

Penetrations of cavity barriers shall be restricted to those illustrated above. All openings through cavity barriers must be no larger than necessary and be fire stopped. The fire stopping shall not restrict thermal movement.

### 3.11.8 Raised floors with or without accessible panels

The construction of raised floors with or without accessible panels shall comply with the following requirements :

- (a) The supporting structure shall be constructed of non-combustible materials having a melting point of at least 800°C, and
- (b) The concealed space between the structural floors and raised floor shall not be used for storage purpose, and
- (c) No services or installation shall be permitted within the concealed space other than

- (i) electrical wiring in metal conduit and metal trunking in compliance with the requirements of SS CP 5 Code of Practice for Wiring of Electrical Equipment of Buildings;
  - (ii) communication cables for computer equipment
  - (iii) fire protection installations serving the area, and
- (d) Where the raised floor is used as a plenum, requirements in Cl.7.1.1 (f) shall be satisfied, and

*(See clause 7.1.1 (f) for illustration)*

- (e) Decking of the raised floor shall be constructed of non-combustible material or where combustible material is used as core material, if allowed in the case of sprinkler protected buildings, the top, bottom, all sides and cut edges shall be covered with material with surface property complying with Class 0 (excluding materials for floor finishes), and




Diagram 3.11.8 (e)-1

*Non-combustible raised floor panels and supports are allowed to be used in non-sprinkler or sprinkler protected buildings.*




Diagram 3.11.8(e)-2

*Raised floor panel constructed of combustible core, eg. chipboard, shall only be allowed to be used in buildings protected by sprinkler system*

- (f) In the case of raised floors with accessible panels, access sections or panels shall be provided such that all concealed spaces between the structural floor and raised floor are easily accessible, and
- (g) Openings in the raised floor for entry of electrical cables shall be effectively closed to prevent entry of debris or other combustible material into the concealed spaces, and
- (h) All sides shall be properly sealed, and
- (i) The concealed space shall be sub-divided by cavity barriers such that the maximum unobstructed area within the concealed space does not exceed 930m<sup>2</sup>, and
- (j) Where the concealed space is fitted with an automatic sprinkler system which complies with the requirements in Chapter 6, cavity barriers are not required, and
- (k) The height of concealed space measured between the top of the structural floor and underside of the raised floor decking shall not exceed 400mm and shall be fitted with automatic smoke detection system complying with requirements of SS CP 10 Code of Practice for the Installation and Servicing of Electrical fire Alarm Systems; and in the case of sprinkler protected building, the height of concealed space may exceed 400mm if the space is fitted throughout with an automatic sprinkler system which complies with the requirements in Chapter 6.




Diagram 3.11.8 (k)

The provision of cavity barriers shall comply with Table 3.11A of the Fire Code.

Non-sprinkler protected building

Cavity barriers shall be provided in accordance with Table 3.11A. The height of concealed space (H), measured between the finished floor level and the underside of the raised floor decking shall not exceed 400mm. The concealed space shall be fitted with smoke detection system in accordance with SS CP 10 Code of Practice for the Installation and Servicing of Electrical fire Alarm Systems. SS CP 10 also allows that smoke detector system is not required to be provided in concealed space which does not exceed 150mm in height – cl.2.1.3.1(b). Sprinkler system is applicable if the height of concealed space exceed 400mm.

Sprinkler protected building

Cavity barriers shall be provided in accordance with Table 3.11A. Where the height of the concealed space does not exceed 400mm, smoke detection system complying with SS CP 10 shall be provided. The height of concealed space may exceed 400mm if the space is fitted throughout with sprinkler system. Where sprinkler system is provided inside the concealed space, cavity barriers are not required to be provided – subclause (j).

- 3.11.8 (l) Where the height of concealed space measured between the top of the structural floor and the underside of the raised floor decking is less than 50mm, the requirements on provision of cavity barriers shall not be applicable.

(No illustration)

3.11.9 Provision for concealed spaces between floor or roof and suspended ceilings

The Relevant Authority may consent to exempt from provision of cavity barriers within the concealed spaces of suspended ceiling, provided the following requirements are complied with :-

- (a) The concealed space shall not be used for storage purpose, and
- (b) The supporting elements shall be constructed of non-combustible material, and
- (c) The exposed surfaces within the concealed space is of class 0 flame spread, (excluding surfaces of any pipe, cable, conduit or insulation of any pipe) and
- (d) In the case of a detector protected building, if the concealed space does not exceed 800mm in depth or if the concealed space is fitted with detectors which comply with the requirements of Chapter 6.
- (e) In the case of a sprinkler protected building:
  - (i) if the concealed space does not exceed 400mm in depth, or
  - (ii) if the concealed space exceeds 400mm and does not exceed 800mm in depth and no combustible material is used within the concealed space, (where the combustible content is small in quantity, the Relevant Authority, may at its discretion, rule that such combustible content may be irrelevant in relation to this sub-clause), or
  - (iii) If the concealed space is fitted with an automatic sprinkler system which complies with the requirements of Chapter 6.
- (f) In the case of other buildings, if the concealed space does not exceed 800mm in depth.

### Detector protected building




Diagram 3.11.9(d)

Provision of cavity barriers in concealed ceiling space is not required if the following requirements are complied with :

- the space is not used for storage purpose; and
- the supporting elements eg. ceiling hangers or supports are constructed of non-combustible material; and
- the exposed surfaces within the concealed space is of Class 0 flame spread (excluding surfaces of any pipe, cable, conduit or insulation of any pipe or duct); and
- concealed space does not exceed 800mm in depth; if exceeds 800mm, it shall be fitted with smoke or heat detectors.

### Sprinkler protected building - Depth of ceiling space does not exceed 400mm




Diagram 3.11.9(e)(i)

Provision of cavity barriers in the concealed ceiling space is not required if the following are complied with :

- a) the space is not used for storage purpose; and
- b) the supporting elements eg. ceiling hangers or supports are constructed of non-combustible material; and
- c) the exposed surfaces within the concealed space is of Class 0 flame spread (excluding surfaces of any pipe, cable, conduit or insulation of any pipe or duct); and
- d) concealed space does not exceed 400mm in depth.

Sprinkler protected building - Depth of ceiling space exceeds 400mm but not exceeding 800mm




Diagram 3.11.9(e)(ii)

Provision of cavity barriers in the concealed ceiling space is not required if the following are complied with :

- a) the space is not used for storage purpose; and
- b) the supporting elements eg. ceiling hangers or supports are constructed of non-combustible material; and
- c) the exposed surfaces within the concealed space is of Class 0 flame spread(excluding surfaces of any pipe, cable, conduit or insulation of any pipe or duct);

and

- d) no combustible is used within the concealed space. However, where the combustible content is small in quantity, the SCDF "FSSD" may, at its discretion grants exemption, provided the space is protected by sprinklers installed on the extended basis under sub-clause 6.6.1.2 of SS CP 52.



Concealed space is sprinklered protected – in accordance with Chapter 6




Diagram 3.11.9(e)(iii)

Provision of cavity barriers in the concealed ceiling is not required. See also cl.3.11.10 for further relaxation.

Other building – which neither requires detector nor sprinkler system




Diagram 3.11.9(f)

Provision of cavity barriers in the concealed ceiling space is not required if the following are complied with :

- a) the space is not used for storage purpose; and
- b) the supporting elements eg. ceiling hangers or supports are constructed of non-combustible material; and
- c) the exposed surfaces within the concealed space is of Class 0 flame spread (excluding surfaces of any pipe, cable, conduit or insulation of any pipe or duct); and

### 3.11.10 Exemption of cavity barriers in ceiling space

Where the concealed space of suspended ceiling is fitted with an automatic sprinkler system which complies with the requirements in Chapter 6,

- (a) The concealed space may be exempted from provision of cavity barriers, and
- (b) Combustible materials and materials with other than Class 0 flame spread may be used for the supporting elements and exposed surfaces of materials within the concealed space, provided the ceiling is not situated over an exit passageway, smoke-stop lobby or other designated means of escape facilities.

(No illustration)

- i) Where the concealed ceiling space is protected by automatic sprinkler system, the above clause allows the following :
  - a) *Provision of cavity barrier is exempted;*
  - b) *Combustible materials such as hardwood timber hangers for ceiling; and*
  - c) *Exposed surfaces within the ceiling space may be of any class other than Class 0 flame spread ie. timber members.*
- ii) *The above relaxation shall not apply if the above ceiling construction is situated over an exit passageway, smoke-stop lobby or other designated means of escape facilities.*

### 3.11.11 Suspended ceiling over protected areas

The concealed spaces of suspended ceiling over an exit passageway, smoke-stop lobby, exit staircase or other designated means of escape facilities, shall comply with the following:

- (a) the ceiling supporting elements and the ceiling shall be constructed of non-combustible materials; and
- (b) the exposed surfaces within the concealed space shall be of Class 0 surface flame spread.




Diagram 3.11.11

The main concern is that spaces meant for safe escape of occupants shall be kept free of combustible materials. Common corridors are treated as escape routes. The exposed surfaces within ceiling space shall have a flame spread rating of Class '0'.

- 3.11.11 (c) Where sprinkler system is installed within the concealed spaces at smoke stop lobby/fire fighting lobby, the ceiling supporting elements and its exposed surface may have a surface spread of flame not lower than class 2.

(No illustration)

3.12.1 General provision

Openings for pipes, ducts, conduits or cables which pass through any part of an Element of Structure (except for a part which does not serve as a fire resisting barrier) or Cavity Barrier shall be :

- (a) Kept as few in number as possible, and
- (b) Kept as small as practicable, and
- (c) All gaps shall be filled with fire-stopping material.

## Fire stopping to a pipe in a compartment wall




Diagram 3.12.1

Fire stopping is concerned with ensuring that the fire-resisting capability of a component ,i.e separating wall, compartment wall/floor, cavity barrier is not diminished or impaired when penetrated by services for example, a pipe, ducts etc.

Therefore whenever gaps are created by the penetration of such pipes, ducts in the fire rated wall/floor, they must be kept as few as possible. The spacing and internal diameter of pipes passing through any elements of structure or cavity barrier shall comply with Cl.3.9.3 and Table 3.9A

### **3.1.2 FIRE STOPPING**

#### 3.12.2 Fire stopping

Fire stopping shall be of material having the necessary fire resistance when subjected to test under BS 476 Pt 20 or other acceptable standards.

(No illustration)

#### 3.12.3 Materials for fire-stopping

Suitable fire stopping materials include:

- (a) Proprietary fire stopping and sealing systems (including those designed for service penetrations) which have been shown by test to maintain the fire resistance of the wall or

other element, subject to approval by the Relevant Authority.

- (b) Other fire-stopping materials include:
- (i) cement mortar;
  - (ii) gypsum based plaster;
  - (iii) cement or gypsum based vermiculite/perlite mixes;
  - (iv) glass fibre, crushed rock, blast furnace slag or ceramic based products (with or without resin binders), and
  - (v) intumescent mastics.

The method of fire stopping and choice of materials should be appropriate to the situation and its application.

(No illustration)

*To prevent displacement, materials used for fire-stopping should be reinforced with (or supported by) materials of limited combustibility in the following circumstances:*

- (i) in all cases where the unsupported span is greater than 100mm, and*
- (ii) in any other cases where non-rigid materials are used (unless they have been shown to be satisfactory by test).*

*Preference should be given to proprietary fire-stopping and sealing system.*

*When cement mortar or gypsum board plaster or cement or gypsum based vermiculite/perlite mixes is used as fire stopping material, care should be exercised to ensure that workmen properly fill up the entire gaps with the appropriate fire stopping material instead of carrying cosmetic application by just filling up the gaps superficially.*

### 3.13 RESTRICTION OF SPREAD OF FLAME OVER SURFACES OF WALLS AND CEILING

#### 3.13.1 Requirements for Class 0

Any reference to a surface being Class 0 shall be construed as a requirement that -

- (a) The material of which the wall or ceiling is constructed shall be non-combustible throughout; or
- (b) The surface material (or, if it is bonded throughout to a substrate, the surface material in conjunction with the substrate) shall have a surface of Class 1 and if tested in accordance with BS 476: Part 6 shall have an index of performance (I) not exceeding 12 and a sub-index (I) not exceeding 6.

(No illustration)

*BS 476:Part 6 refers to a standard fire test for propagation of products. Under this test, there is a means of comparing the contribution of combustible building materials to the growth of a fire by providing a measure of the rate of heat evolution of the samples, exposed in a small combustion chamber.*

*The performance of each sample is expressed as a numerical index from 0 to 100 or more. Low values of the indexes indicate a low rate of heat release. Three to five specimens are tested.*

*Index of performance  $I = i_1 + i_2 + i_3$  where sub-index  $i_1$  is derived from the first three minutes of test,  $i_2$  from the following seven minutes, and  $i_3$  from the final ten minutes. A high index  $i_1$  indicates an initial rapid ignition and heat release.*

#### 3.13.2 Requirements for a class other than Class 0 classification

Any reference to a surface being of a class other than Class 0 shall be construed as a requirement that the material which the wall or ceiling is constructed shall comply with the relevant test criteria as to surface spread of flame specified in relation to that class in BS 476: Part 7.

(No illustration)

*Test under BS 476: Part 7 refers to a standard fire test for the classification of the surface spread of flame of products.*

*This test is able to determine the tendency of surfaces of flat materials to support the spread of flame across their surfaces and specifies a method of classification appropriate to wall and ceiling linings. Class 1 represents the best performance, followed in descending order by Class 2, Class 3 and Class 4.*

3.13.3 Class 0 shall be regarded as the highest class followed in descending order by Class 1, Class 2, Class 3 and Class 4, as set here under:

- \* Class 0 - Surface of no Flame Spread. Those surfaces that conform to the requirements of Cl. 3.13.1.
- \* Class 1 - Surface of Very Low Flame Spread. Those surfaces on which not more than 150mm mean spread of flames occurs under the relevant test conditions.
- \* Class 2 - Surface of Low Flame Spread. Those surfaces on which during the first 1½ minutes of test, the mean spread of flame is not more than 375 mm and the final spread does not exceed 450 mm under the relevant test conditions.
- \* Class 3 - Surface of Medium Flame Spread. Those surfaces on which during the first 1½ minutes of test, the mean spread of flame is not more than 375 mm and during the first 10 minutes of test is not more than 825 mm under the relevant test conditions.
- \* Class 4 - Surface of Rapid Flame Spread. Those surfaces on which during the first 1-1/2 minutes of test the mean spread of flame is more than 375 mm and during the first 10 minutes of test is more than 825 mm under the relevant conditions.

(No illustration)

*The reason for having Class 0 is that Class 1 covered too wide a range of performance for use in critical areas. Where a higher degree of protection is required, for example in smoke stop lobbies, exit staircases, exit passageways (which constitute the escape route), Class 0 is specified.*

### 3.13.4 Class of flame spread to be not lower than specified

The surface of a wall or ceiling in a room/space shall be of a class not lower than specified as relevant in the Table 3.13A, provided that -

- (a) Where an automatic sprinkler system is fitted throughout in the building in compliance with the requirements in Chapter 6, there is no control on the surface of flame rating in room / space, except for the following occupancies / usage:
  - (iii) Exit staircase, exit passageway and smoke-stop / fire fighting lobbies.
- (b) Where a building is not protected by automatic sprinkler system, surfaces of the walls and ceilings may be of a surface class not lower than class 3 to the extent permitted by Cl 3.13.5 (a) and Cl 3.13.5 (b) respectively.




Diagram 3.13.4

Wall and ceiling finishes to exit staircase (including exit passageway) shall be of non-combustible materials or Class 0 ( if sprinkler protected). For rooms, the extent of wall and ceiling finishes ( no control if sprinkler protected or class 1 if not sprinkler protected ) shall comply to Cl.3.13.5 (a) and (b) respectively for area that can not be lower than class 3.




3.13.5 (a) Where class of flame spread may be of any class not lower than class 3

Any part of the surface of a wall in a room or compartment may be of any class not lower than Class 3 if the area of that part ( or if there are two or more such parts, the total area of those parts) does not exceed the following -

(ii) in any other case, 60 m<sup>2</sup>.

Fig.(1)



Planal/Isometric view

Diagram 3.13.5(a)(ii) - 1

Computation of 60m<sup>2</sup> will be based on total surface areas having not lower than Class 3 of walls 1 + 2 + 3 + 4.

Fig. (i)




Fig. (II)




Fig. (III)




Diagram 3.13.5(a)(ii) – 2

In situation where multiple floors are interconnected to form one compartment by atrium design, waiver application is required to vary the max. 60sq.m

For Class 3 wall finishes, the total area of 60sq.m excludes :

- (i) door frames and unglazed parts of doors;
- (ii) window frames and frames in which glazing is fitted;
- (iii) architraves cover moulds, picture rails, skirtings and similar narrow members; and
- (iv) fitted furniture.






Diagram 3.13.5(b)(ii)

- Factories and warehouses are usually provided with translucent roof sheets or sky light for natural lighting.
- Any part of ceiling which is combustibile shall have an area not exceeding 5m<sup>2</sup> and a class not lower than Class 3 flame spread. It shall be separated from any such part by at least 1.8m
- The aggregate area of such part of ceiling shall not exceed 20% of the floor area of the room or compartment.

(iii) that part and all other such parts are evenly distributed over the whole area of the ceiling and together have an area which does not exceed 20% of the floor area of the room, or

Unenclosed loading/unloading platform




Diagram 3.13.5(b)(iii) - 1

Covered linkway connecting 2 buildings




Diagram 3.13.5(b)(iii) - 2

*In-addition to the above, ceilings to balcony, verandah, open carport are also allowed to have not lower than Class 3 flame spread. The above relaxation is allowed as the ceilings are located at the periphery of the building where smoke and heat could easily be dispersed into the exterior air.*

- (iv) the ceiling is that of a balcony, verandah, open carport, covered way or loading bay which (irrespective of its floor area) has at least one of its longer sides wholly and permanently open, or




Diagram 3.13.5(b)(iv) - 1




Diagram 3.13.5(b)(iv) - 2




Diagram 3.13.5(b)(iv) - 3

A garage or outbuilding may have ceiling not lower than Class 3 flame spread, provided the gross floor area does not exceed 40m<sup>2</sup>

- (v) the ceiling is that of a garage or outbuilding which ( irrespective of whether it forms part of a building or is a building which is attached to another building or wholly detached ) has floor area not exceeding 40 m<sup>2</sup>.

### 3.13.6 Exception

Wall and ceiling finishes in the form of thin sheet of not more than 1.0 mm thickness mounted on a non-combustible substrate will not be subject to the requirement of surface spread of flame provisions provided that this exception shall not apply to smoke-stop / fire fighting lobbies, exit staircases and passageways.

(No illustration)

*The above clause grants relaxation on the control of wall and ceiling finishes which are not more than 1.0 mm thick mounted on non-combustible substrate, provided these finishes are not used in smoke-stop lobbies, exit staircases and exit passageways. The main concern is that all protected routes meant for escape of occupants shall be kept free of combustible finishes.*

## 3.14 ROOFS

### 3.14.1 Roof construction

Surface of materials for roof covering and roof construction shall have a surface spread of flame rating not lower than class 1, except in the case of buildings that are protected throughout with automatic sprinkler system in compliance with Chapter 6.

(No illustration)

### 3.14.3 Roof junction with separating wall and compartment wall

At the junctions with separating wall or compartment wall, roof construction shall comply with the relevant requirements under Cl.3.6.3 and Cl.3.7.4 respectively.

*(See illustration and comments under Cl.3.6.3)*

### 3.14.4 Roof terrace

Roof terrace shall not be roofed over. If it is either partially or fully roofed over, it shall be considered as a habitable floor.




Diagram 3.14.4

### Roof Terrace

#### a) Means of escape

Roof terrace even if not roofed over could be used by building owners to hold private functions. In this respect, the roof terrace would attract additional occupant load, which could be sizeable, depending on the type of function proposed, for example, a private dinner function could be held on the open roof terrace. The guests and the hosts that are attending the private function on the roof terrace would be subject to the risk of a fire that could break out in any of the floor space below the roof terrace. For this reason, roof terrace, whether roof over or not should be subjected to compliance with exit capacity and travel distance requirements under the fire code. Roof terrace which exceeds the floor area of 60sq. m shall be provided with a separate exit at terrace level.

#### b) Habitable height

For the purpose of determining the habitable height of a building, roof terrace that is either partially or fully roofed over shall be considered as a habitable floor. Thus, if the roof terrace is the highest habitable floor, the habitable height of a building shall be measured from the lowest level of the fire engine access road to the finished floor level of the highest habitable floor.

In the above diagram, the habitable height of the building shall be measured up to the finished floor level of the terrace. Otherwise it shall be measured up to the finished floor level of the 3<sup>rd</sup> storey.



### 3.15 MATERIALS FOR CONSTRUCTION

- 3.15.1 (a) Materials used in the construction of building elements shall comply with the provisions stated under this section in addition to the performance requirements such as for fire resistance and limit to spread of flame as stipulated in other relevant sections of the code.
- (c) Flame retardant chemicals are permitted to be used for upgrading of fire resistance rating or surface spread of flame of timber or any combustible materials, subject to the following:
- (i) The chemical treatment process is part and parcel of the manufacturing process to produce the finished product ;
  - (ii) The chemical treatment is by means of pressure impregnation conforming to SS CP: 1 – Use of Timber in Building Construction , or the manufacturer's specification in accordance to the prototype test, for timber and other combustible materials respectively.
  - (iii) The treated materials/products have been subjected to fire test as required under Cl 3.4.1 or Cl 3.13.1

(No illustration)

1. *It is recognised as an alternative means to protecting timber construction in buildings.*
2. *However, we have to understand the limitations on the use of flame retardant chemicals for upgrading of fire resistance and/or surface spread of flame rating of combustible materials. The limitations are as follows:-*

- a. *The chemicals may deteriorate after exposing to the environment for a long duration. After such, the fire resistance performance or the surface spread of flame rating may be adversely affected over time.*
  - b. *The inherent property of the flame-retardant chemical to resist fire spread may be affected when cleaning agent is constantly applied to the surface of the combustible material.*
  - c. *There is no specific method and control of treatment of the flame-retardant chemical. This would lead to poor performance as a result of shoddy construction of the materials.*
  - d. *There is no certainty on the duration for which the fire property in a material applied with such a chemical can last.*
3. *For buildings which are not under Conservation, the use of timber materials should be carefully considered and should be avoided where possible.*
  4. *Building owners and occupiers should be made aware of the above mentioned limitations on the use of flame retardant chemicals. In the course of using the premises, building owners and occupiers shall not do anything to cause the retardant treatment to timber members to deteriorate.*

3.15.2 All elements of structure shall be constructed of non-combustible materials in addition to the relevant provisions as follows:

Cl.3.3 for fire resistance of elements of structure,  
 Cl.3.5.1, 3.5.2 & 3.5.4 for External Walls,  
 Cl.3.6.1(c)/(d) & 3.6.5 for Separating Walls,  
 Cl.3.7.1(c)/(d), 3.7.5 & 3.7.6 for Compartment Walls and  
 Compartment Floors,  
 Cl.3.8.2(c), 3.8.4, 3.8.7(c), 3.8.8(b), 3.8.8(e) and 3.8.9(a) for  
 Protected Shafts.

3.15.3 Materials used for the protection of openings shall comply with the relevant provisions of cl.3.9 of the code for protection of openings.

3.15.4 Exit staircases shall be constructed of non-combustible materials to comply with the provision of Cl.3.10.1.

*(See Cl.3.10.1 to 3.10.4 for illustration and explanation)*

3.15.5 Materials used for the construction of raised floors shall comply with the provisions of cl.3.11.8(a) and cl.3.11.8(e).

3.15.6 Materials used for construction of ceiling and its supports shall comply with Table 3.13B, except for supports that are required to comply with cl.3.11.9 (b).

3.15.7 Construction of ceilings and ceiling supports located within sprinkler protected building shall comply with the provision of cl.3.11.10(b).

3.15.8 Materials used for fire stopping shall comply with the relevant provisions of cl.3.12.2 and 3.12.3.

3.15.9 Materials used on the surfaces of walls and ceilings are required to meet the requirements for restriction of spread of flame and to comply with the performance requirements as stipulated under cl.3.13.

3.15.10 Materials used for roof construction shall comply with the provisions of cl.3.14.1.

3.15.11 Internal non-load bearing walls in buildings shall comply with Table 3.13B and the materials for surface finishes of internal non-load bearing walls shall not be treated as part of the wall and shall comply with the relevant provisions of cl 3.13.

*(No illustration)*

*Materials for surface finishes of all the walls, non-load bearing, separating and compartment walls shall comply with Cl.3.13.5 and Cl.3.13.6.*

3.15.12 (a) Composite panels which consist of plastic core shall not be used either for the construction of internal non-load bearing walls, ceilings, external walls or as cladding to external walls of all buildings unless prior approval has been obtained from the Relevant Authority.

*(No illustration)*

Composite panels are used as external walls or cladding of external walls to buildings. Prior approval should be obtained before any composite panel is erected on site. The main concern is that composite panels when subjected to fire would burn vigorously to produce thick, poisonous fumes.

- (b) Materials with surface flame spread rating of not lower than Class 3 shall be permitted to be used for the construction of partition for toilet cubicles. If the material used is of Class 3 surface flame spread rating, total exposed surface area of the partitions within the toilet shall not be more than 60m<sup>2</sup>.



Diagram 3.15.12 (b)

Materials with surface flame spread rating of not lower than Class 3, including phenolic panels, are allowed to be used in the construction of partitions for toilet cubicles only.

The exposed surface area of not more than 60m<sup>2</sup> of the partitions within the toilet refers to the surface exposed to air, inside and outside, of the partitions.

The reasons for allowing materials with surface flame spread rating of not lower than Class 3, including phenolic panels, in the construction of toilet cubicles are:-

- a. toilets are considered as wet areas;
- b. the amount of combustible materials would be limited;
- c. the toilets are subjected to low transient occupancy.

3.15.13 Fire rated glass wall/door to compartment walls, compartment floors, smoke stop lobby and fire fighting lobby, and protected shafts not containing exit staircase and fire lift.

- (a) The walls and doors shall have the necessary fire resistance, including insulation, when subject to test under BS 476: Part 20-23; and
- (b) The walls and doors shall meet the class A of the Impact Performance requirements when subject to test under BS 6206 or AS 2208.

3.15.14 Internal non-load bearing walls, ceilings and finishes shall not contain any plastic material.