

CHAPTER 8 OTHER SYSTEMS

8.1 EXIT LIGHTING AND EXIT SIGN

8.1.1 Exit Lighting

- (a) Exits of all buildings, except for purpose group I, shall be provided with artificial lighting facilities to the satisfaction of the requirements under this Code.




Diagram 8.1.1(a)

- (i) When a fire occurs in a building, the degree of visibility in corridors, staircases and passageways plays a vital part in facilitating evacuation of occupants.
- (ii) Street lightings should not be relied upon to provide the emergency lighting as they could malfunction or there could be district power failure during an emergency or they could be shaded by trees/building structures. All buildings shall be self-sufficient in the provision of artificial lightings without any dependence on other or external sources.
- (b) The minimum illuminance to be provided for all exits and the spacing for luminaires shall be in accordance with the requirements in SS CP 19 Code of Practice for the Installation and Maintenance of Emergency Evacuation Lighting and Power Supply Systems in Buildings.

- (c) The delay between the failure of the electrical supply to normal lighting and the energization of the exit lighting shall not exceed 1 second.

(No illustration)

SS.CP 19 requires that horizontal illuminance in the centre line of any escape route shall not be less than 0.5 lux, measured at the floor, for minimum duration of 1 hour.

The positioning of lighting shall be so arranged that the failure of any single lighting unit, such as the burning out of a bulb, will not leave any area in darkness.

For critical areas, such as exit staircases, internal and external exit passageways, there shall be no interruption of illumination exceeding 1 second during the changeover from one energy source to another. This would ensure that occupants could see their way down the exit staircases without fear of tripping. For ease of reference, the value of 1 foot candle is equivalent to 10 lux, measured at the floor.

8.1.2 Emergency Lighting for Corridors and Lobbies

- (a) Emergency lighting shall be provided in all corridors and lobbies of all buildings except purpose group I.
- (b) The minimum level of illuminance, the spacing of luminaires and the maximum delay for emergency lighting required in this Clause shall be the same as that for the exit lighting.

(No illustration)

The requirements for provision of emergency lighting for corridors and lobbies in respect of:

- *min. level of luminance;*
- *spacing of luminaires; and*
- *delay (1 second) for the emergency lighting are similar to clause 8.1.1.*

Corridors and lobbies, including routes of escape, smoke stop lobbies, common lobbies are required to have min. 0.5 lux, measured at the floor, for minimum duration of 1 hour, notwithstanding that occupants may be presumed to be familiar with exit facilities by reason of regular usage of such facilities.

The emergency lighting system shall be so arranged to provide the required illumination by means of standby generator set upon failure of public utility supply. The changeover from one energy source to another shall not incur a delay of more than 15 seconds. This is consider a reasonable short time for the generator to start. However, where batteries are used for emergency power, they must be the type that will automatically be kept charged and be able to perform for a minimum duration of 1 hour.

8.1.3 Emergency Lighting for Occupied Areas

- (a) For all buildings except purpose group I or II, emergency lighting shall be provided in the occupied areas following the guidelines below:
 - (i) along paths leading to corridors, lobbies and exits in all occupied areas where the direct distance from the entry point of the corridor, lobby or exit to the furthest point in the area concerned exceeds 13m; or
 - (ii) over the whole of such area if there are no explicit paths leading to corridors, lobbies and exits.
- (i) *Room having a direct distance > 13m and designed with defined escape path shall be provided with emergency lighting along paths leading to the exit.*




Diagram 8.1.3(a)(i)

- (ii) Room having a direct distance $> 13\text{m}$ and not provided with defined escape path or where escape path is not defined, shall be provided with emergency lighting to cover the whole floor space. The level of illuminance shall comply with CP 19.




Diagram 8.1.3(a)(ii)

- 8.1.3 (b) Notwithstanding the requirements in (a) above, emergency lighting shall be provided in the following locations:
- (i) Lift cars as stipulated in this Code;
 - (ii) Fire command centres;
 - (iii) Generator rooms;
 - (v) Fire pump rooms;
 - (vi) Areas of refuge within the same building.
- (c) The minimum level of illuminance shall comply with the requirements in SS CP 19.
- (d) The delay between the failure of the electrical supply to normal lighting and the energization of the emergency lighting for occupied areas shall not exceed 15 seconds.
- (No illustration)*

Emergency lighting is required to be provided to generator rooms and fire pump rooms to enable maintenance personnel to evacuate safely in times of power failure. The emergency lighting would help fire fighters if there is a need to gain access into any of these rooms or spaces. Basement car parks are also required to be provided with emergency lighting regardless of the floor area. It would help to lead public to the nearest exit escape routes. Car lighting cannot be taken and relied upon as emergency lighting.

8.1.4 Emergency lighting for fire fighting facilities

(a) Fire fighting facilities

Fire alarm panels, fire alarm call points and fire fighting equipment shall be adequately illuminated at all times so that they can be readily located.

(b) The minimum level of illuminance shall comply with the requirements in SS CP 19.

(c) The delay between the failure of the electrical supply to normal lighting and the energization of the emergency lighting for fire fighting facilities shall not exceed 15 seconds.

Emergency lighting to breaching inlets/alarm call point




Diagram 8.1.4

The emergency lighting system shall be so arranged as to provide the required illumination automatically at places where fire fighting facilities are provided e.g. breaching inlets, fire alarm panels, fire alarm call points, sprinkler control valve etc.

This is to facilitate the occupants and fire fighters to locate the fire fighting facilities. The emergency illumination shall not incur a delay of more than 15 seconds during the changeover from normal supply to secondary source via generator supply.

8.1.5 Secondary Source of Power Supply

- (a) The delay for energization of the exit and emergency lighting systems between normal supply and the secondary source shall be as stipulated in the relevant clauses.
- (b) Duration of the secondary source of power supply shall comply with the requirements in SS CP 19.
- (c) Location, arrangement and control, installation of electrical wiring of the secondary source of supply, be it in the form of battery, standby generator, inverter or other accepted equipment, shall comply with the requirements in SS CP 19.

(No illustration)

- (i) Where maintenance of illumination depends upon changing from normal power supply to secondary source via generator sets, there should be minimal delay during the switchover, which should not exceed 15 seconds;*
- (ii) The emergency lighting system shall be capable of maintaining a supply of at least 1 hour, long enough for evacuation of occupants and to serve the initial stage of fire fighting;*
- (iii) Generally, the time for changeover should not exceed 15 seconds for emergency lighting to be provided at occupied areas and at places where immediate visibility is not essential. As for critical areas such as exit points and along defined exit routes the min. level of lighting must be available at all times so that occupants when making their escape would not panic.*

8.1.6 Luminaire

All exit and emergency luminaires required by this Code shall be of approved type as specified in SS CP 19.

(No illustration)

Besides complying with SS CP 19, all exit and emergency luminaires should be of the approved type under the PSB Product Listing Scheme and bear PSB label or mark.

8.1.7 Exit and Directional Signs

- (a) In all buildings, except for purpose group I and II, the entrance to every exit on every floor shall be clearly indicated by an exit sign placed over the exit door. Such signs shall be placed so as to be clearly visible at all times.

Exit signs to exit on every floor






Diagram 8.1.7 (a)

Decorations, furnishings or equipment, which would either interfere or impair with the visibility of an exit sign shall not be allowed; nor shall there be any brightly illuminated sign (for other than exit purposes), display or object in or near the line of vision to the required exit sign.

(b) Directional signs

In long corridors, in open floor areas, and in all situations where the location of the exits may not be readily visible, directional signs shall be provided to serve as guides from all portions of the corridors or floors.







Diagram 8.1.7(b) - 1

The above diagrams are just a few common variations of the positioning of directional signs. Readily visible signs shall mark access to exits where the exit or way to reach it is not immediately visible to the occupants. Sign placement shall be such that no point along the exit route is more than 30m from the nearest visible sign. Directional signs shall be placed at suitable locations along exit routes at max. 30m intervals.




Diagram 8.1.7(b) - 2

In institutional occupancy areas, exit directional signs are to be placed at strategic location so that occupants could rely on the signs to evacuate in times of emergency.

8.1.7 (d) Signages

Where the Relevant Authority has allowed under subclause 2.3.5(d) upper storey staircase to be continuous with that serving the basement, appropriate signages, including pictorials shall be placed at strategic location inside the staircase to direct occupants out of the building in times of emergency.

Applicable only if staircase serves 4 storeys (including basement) or less and entry into the staircase from the basement is through a 1 hour rated fire door





Diagram 8.1.7(d) -

This can be done by placing a physical barrier to prevent occupants from continuing below the level of exit discharge into the basement. This helps to warn occupants in the staircase enclosure that they are on the level of exit discharge.

- (i) Clause 2.3.5(d) allows upper storey staircase to be continuous with that serving the basement, which is naturally ventilated.
- (ii) To prevent occupants exiting continuously from upper storeys into the basement floor during an emergency, a physical barrier in the form of a door or a gate (as shown above) could be provided across the staircase landing at ground level to separate the discharge route of upper storeys from the basement staircase.

- (iii) In addition, appropriate signages should be provided inside the staircase enclosure to direct occupants out of the building at ground level.

Staircase serving more than 4 storeys (including basement)



- (e) The legends, dimensions, design and installation of the exit signs and directional signs shall comply with SS CP 19.

(No illustration)

All exit and emergency luminaires should be of the approved type under the PSB Product Listing Scheme and bear PSB label or mark.

- (f) Self-illuminating signs

Self-illuminating exit and directional signs with letters in green and powered by radioactive material are allowed for use in buildings, provided the signs comply with BS 5499 Part 2, SS 364 and SS CP 19 under sub-clause 8.1.7(e).




Diagram 8.1.7(f)

(No illustration)

Self-illuminating exit signs powered by radioactive material do not have the required minimum 50 lux illuminance on the face of the signs. To meet the requirement of CP 19, the signs can be externally lit by a nearby emergency luminaire. The light from the emergency luminaire shall be able to provide the required minimum 50 lux illuminance on the face of the sign. Building owners must observe the safety requirements on the disposal of signs when the life span expired.

SCDF(FSSD)'s circular dated 24 Sept 2003

RIs (arch) are only required to check on the provision/location of the emergency luminaries, including self-contained light fittings, in the buildings. For the emergency lighting that are powered by battery-pack or central battery system or uninterrupt power supply system (UPS) and linked to emergency generator set, the RIs (M&E) shall conduct test on the emergency lighting systems to ensure that they conform to CP 19:2002.

8.2 VOICE COMMUNICATION SYSTEM AND FIRE COMMAND CENTRE

8.2.1(a) System requirements

One way emergency communication system and a fire command centre shall be provided as follows:

(i) For all large buildings under purpose group III (excluding educational buildings such as schools, colleges), (gross floor area greater than 5000 sq m or having a total occupant load exceeding 1000 persons).

(ii) Construction

For all buildings belonging to purpose group III, of more than 24m in habitable height.

(iii) For health care occupancies of less than 24m in habitable height. Loudspeakers for the public address system shall be provided in every lift lobby, staircase enclosure and other strategic positions within audible distance of all parts of all storeys of the building.

(No illustration)

During fire emergency, the ordinary public address system or one-way emergency communication system will be used to notify occupants in the building. Under phase evacuation, occupants will be advised to relocate to 'Safe area of refuge' in which to wait out the fire. Occupants could also be advised to evacuate the building during fire emergency. In phase evacuation, communication with these people can be maintained to prevent panic and to allow further relocation, if necessary. The ordinary public address system may be permitted to be used for other announcements.

The following shall be provided :

a)

A Fire Command Centre

b)

An ordinary public address system

c)

Two-way emergency communication system between Fire Command Centre and every fire fighting lobby.

8.2.1(b) Two way emergency communication system shall be provided between the Fire Command Centre, under sub-clauses 8.2.1(a), (i) and (ii) above, and the following area:

- (i) every fire fighting lobby, including 1st storey;
- (ii) all fire fighting related mechanical equipment rooms inclusive of sprinkler pump room, wet rising main pump room, hose reel pump room, switch rooms and generator rooms;
- (iii) all rooms housing smoke control equipment;
- (iv) all lift machine rooms;
- (v) fire lift;
- (vi) each area of refuge; and
- (vii) air-handling control rooms.

(No illustration)

The following shall be provided :

- a) *A Fire Command Centre.*
- b) *One-way emergency communication system.*
- c) *Two-way emergency communication system.*

** The one-way voice communication system shall consist of microphone input, selector switches, amplifiers and remote loudspeakers to perform the functions specified. Loud speakers operated from the Fire Command Centre shall be of sufficient number and appropriate design to provide effective voice communication to the following areas :*

- a) *all habitable rooms;*
- b) *all basement floor areas;*
- c) *all escape staircases;*
- d) *all staircase lobbies and lift lobbies forming parts of the means of escape;*
- e) *the main entrance;*
- f) *all corridors leading to exits;*
- g) *all service areas where people may be working;*
- h) *all areas of refuge*
- i) *all assembling areas;*

- j) all patients' accommodation floors, hostel bedroom floors, etc
- k) all other areas as may be required by SCDF "FSSD".

* The two-way communication system shall consist of the main telephone handset and selector switches at the control console located in the fire Command Centre and the other remote handset installed at various locations as mentioned in the above sub-clause b(l) to (v).

In general, at least one emergency handset shall be located on each floor. When a floor is divided into two or more fire-isolated zones used as areas of refuge for one another, each zone shall be provided with a handset. The criteria to be considered in determining the position of each handset shall be such that, wherever possible, the handset is near the protected staircase or near the central position of the zone covered by it, and as remote as possible from the nearest alarm sounding device.

(Footnote: SCDF(FSSD)'s circular dated 20 Jan 2003 –

In view of the adequacy of the lift intercom system, SCDF(FSSD) will accept the lift intercom system in-lieu of the handset provided it complies with clause 9 of SSCP 25: 1999 on 'Installation and Power Supply'.

- (c) For building of mixed commercial cum residential usage, the requirements of sub-clauses a(ii) of this clause shall be applicable provided that:
 - (i) where the commercial component of the building occupies only the lower portion of the building and is separated from the residential occupancies, then for the purpose of compliance with the said requirements, the measurement of habitable height shall be taken to that part of the commercial component of the building; and
 - (ii) where a commercial component of the building is located above any residential occupancies, the provisions of a(ii) shall be applicable if the habitable height of the building exceeds 24m.

To address the concerns of sleeping risk and patients who are unable to care for their self-preservation and safety in health-care occupancies which are less than 24m in habitable height, an ordinary public address system shall be provided to effect early and orderly evacuation of occupants in times of emergency. The following shall be provided :

The public address system shall consist of the microphone input, selector switches and remote loudspeakers to perform the functions specified. Loud speakers operated from the Fire Command Centre shall be of sufficient number and appropriate design to provide effective voice communication to the following areas :

- a) all habitable rooms;
- b) all basement floor areas;
- c) all escape staircases;
- d) all staircase lobbies and lift lobbies forming parts of the means of escape;
- e) the main entrance;
- f) all corridors leading to exits;
- g) all service areas where people may be working;
- h) all areas of refuge;
- i) all assembling areas;
- j) all patients' accommodation floors;
- k) all other areas as may be required by SCDF "FSSD".

8.2.2 Where a one way or two way emergency communication system is required by this code, it shall comply with the requirements stipulated in SS CP 25: Code of Practice for Emergency Voice Communication Systems in Buildings

(No illustration)


8.2.3 Fire Command Centre

(a) A Fire Command Centre shall be provided in any building, which requires any of the following installation:

- (i) fire lift;
- (ii) emergency voice communication system; and
- (iii) engineered smoke control system.

8.2.3 (b) Size

A Fire Command Centre shall be of adequate size to house all the terminals and supervisory/control equipment, etc of the building's fire protection/detection systems and a free working space of at least 6 sq m.



Planal Isometric view - Fire Command Centre

Diagram 8.2.3 (b)

The actual size of a fire command centre should be provided at plan submission stage. The minimum net working space of 6 sq m shall exclude spaces for equipment and furniture.

(c) Location

A Fire Command Centre shall be located adjacent to the fire lift lobby at the designated storey of the building (ie the lobby of the building on the first storey or immediately adjacent thereto) or at any other location as may be designated by the Relevant Authority.




Diagram 8.2.3(c)

It is desirable that a “Line of sight” could be achieved from the door of fire command centre to the door of the fire lift & firemen staircase. This arrangement would assist greatly the communication linkage amongst the 3 areas & lead to good command of fire fighters moving in & out of the fire lift.

However, where direct linkage between fire command centre & fire lift/staircase could not be achieved, prior approval from FSB should be obtained before building plan submission.


(d) Construction

The construction of enclosure, facilities and lighting of a Fire Command Centre shall comply with the SS CP25: Code of Practice for Emergency Voice Communication Systems in Buildings.

(No illustration)

- (e) Mechanical ventilation where required for the Fire Command Centre shall be provided with standby power supply and shall have ductworks independent of any other ductwork serving other parts of the building.

Mechanical ventilation to Fire Command Centre



Plan

Diagram 8.2.3(e)

The critical usage of fire command centre during fire emergency requires that lighting/ventilation & other power supply should come from standby power source eg generator set. The supply & exhaust ductworks of the mechanical ventilation shall be independent of any other ductwork serving other parts of the building. This is to prevent heat or smoke from being conveyed into the fire command centre via the ducts.

8.2.4 Two-way communication system

All multi-level basements of buildings under purpose group V are required to be provided with two-way emergency communication system between the Fire Command Centre and the following areas:

- (i) Every fire fighting lobby, including 1st storey. In building comprising 2, 3 or 4 basements, one of the smoke stop lobbies shall be designated as a fire fighting lobby;
- (ii) All fire fighting related mechanical equipment rooms, inclusive of sprinkler pump room, wet rising main pump room, hosereel pump, switch rooms, generator rooms, and lift machine room;
- (iii) All rooms housing smoke control equipment;

- (iv) Fire lift;
- (v) Each area of refuge; and
- (vi) Air-handling control rooms.

Exception :

- (i) Single-level basement, irrespective of its usage of building under purpose group IV, V and VII is not required to be provided with two-way emergency communication.

(No illustration)

The above requirement would be applicable to buildings having any basements greater than a depth of 9m from the averaged ground level outside the building. This is to complement the need to provide fire lift to serve the basement storeys under cl.6.6.3(a) of the Fire Code 97.